

The results listed on this page are from residential homes in Chicago that have volunteered to have their water tested for lead as part of a research study. The data that is shown below is quality controlled. The study is ongoing, and the results below are a small portion of the large sample population necessary for statistical evaluation. The data below will be further reviewed prior to inclusion in statistical evaluation. The results are anonymized to the block level, so the complete address of each home is not posted. In cases where a sample tests over 15 parts per billion (the action limit set by the EPA), the Department of Water Management will contact the homeowner to discuss the results and schedule a time to resample the water and inspect the home's plumbing and electrical wiring to better evaluate possible causes. All results are shown in PPB (Parts per Billion). In cases where multiple homes on the same block have results, the location is further amended as "Site 1", "Site 2", etc.

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
9/28/2016	100XX S EGGLESTON AVE	1.9	1.4	1.5	1.3		
2/8/2017	101XX S EGGLESTON AVE	2.0	1.1	1.2	0.6		
3/7/2017	101XX S EGGLESTON AVE	2.1	1.0	1.0	0.7		
1/10/2017	101XX S EGGLESTON AVE	1.8	1.1	1.1	0.7	0.7	
4/4/2017	101XX S EGGLESTON AVE	1.7	1.1	1.1	0.8		
9/28/2016	101XX S EGGLESTON AVE	1.9	1.5	1.8	0.8		
6/6/2017	101XX S EGGLESTON AVE	1.4	1.0	1.1	0.9		
5/9/2017	101XX S EGGLESTON AVE	2.1	1.5	1.4	1.2		
6/20/2017	101XX S RACINE AVE	3.1	4.7	4.4	2.7		
9/29/2016	102XX S EGGLESTON AVE <b>SITE 1</b>	1.9	1.0	0.9	0.6		
1/11/2017	102XX S EGGLESTON AVE <b>SITE 1</b>	1.8	1.9	1.9	0.8		
1/10/2017	102XX S EGGLESTON AVE <b>SITE 2</b>	4.1	4.2	7.9	1.8		
9/28/2016	102XX S EGGLESTON AVE <b>SITE 2</b>	3.8	7.6	10	4.7		
1/12/2017	102XX S EGGLESTON AVE <b>SITE 3</b>	4.8	4.8	8.4	2.3		
10/12/2016	102XX S EGGLESTON AVE <b>SITE 3</b>	5.5	8.0	13	5.3		
11/1/2017	103XX S LOWE AVE	3.0	2.2	1.6	1.3		
9/15/2016	103XX S RACINE AVE	5.5	5.0	18	4.5		
10/8/2016	103XX S RACINE AVE	See Follow-Up Sequential Sampling Table for Results					
11/1/2017	103XX S UNION AVE	1.8	5.1	7.0	1.2		
3/8/2017	104XX S ARTESIAN AVE <b>SITE 1</b>	3.2	3.6	3.9	1.2		
2/8/2017	104XX S ARTESIAN AVE <b>SITE 1</b>	3.7	2.0	3.3	1.3	1.2	
11/17/2017	104XX S ARTESIAN AVE <b>SITE 2</b>	5.3	2.5	2.3	0.8		
11/2/2017	104XX S ARTESIAN AVE <b>SITE 2</b>	2.4	2.3	4.3	1.1		
1/25/2018	104XX S AVENUE E	1.0	2.4	7.0	0.4		
2/27/2018	104XX S AVENUE E	1.4	6.0	11	0.7		
7/28/2017	105XX S RACINE AVE <b>SITE 1</b>	4.4	3.9	12	8.4		
8/8/2017	105XX S RACINE AVE <b>SITE 2</b>	4.3	6.8	7.6	4.3		
2/14/2018	105XX S RACINE AVE <b>SITE 2</b>	6.8	7.1	7.6	7.7		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
1/4/2018	105XX S RACINE AVE <b>SITE 2</b>	6.2	7.6	8.1	8.0		
2/27/2018	106XX S RACINE AVE	0.9	1.3	1.3	0.9		
6/20/2017	106XX S RACINE AVE	1.2	2.6	2.5	2.3		
1/4/2018	106XX S RACINE AVE	1.0	2.4	2.4	3.0		
6/23/2017	107XX S AVENUE N	5.0	14	12	3.1		
7/21/2017	107XX S AVENUE N	5.8	23	15	4.4		
9/6/2017	107XX S AVENUE N	See Follow-Up Sequential Sampling Table for Results					
1/29/2018	108XX S BEVERLY AVE	1.8	2.4	5.2	0.7		
9/15/2016	10XX W 103RD ST	6.4	2.6	4.0	2.0		
2/13/2018	10XX W 107TH ST	0.9	2.0	2.0	1.4		
1/31/2018	117XX S MAPLEWOOD AVE	0.7	0.7	0.6	0.6		
12/15/2016	11XX E 81ST ST	0.8	1.2	2.5	0.4	0.3	
8/25/2016	11XX E 81ST ST	1.2	1.9	2.9	0.9		
12/15/2016	11XX E 81ST ST	3.8	3.3	13	1.0		
8/25/2016	11XX E 81ST ST	2.0	2.2	1.8	1.2	1.2	
6/20/2017	11XX W 102ND ST	3.1	3.0	8.1	1.8	1.8	
1/31/2018	11XX W 102ND ST	4.4	5.3	7.9	1.9		
4/4/2017	11XX W 104TH ST	4.4	2.6	2.3	0.6		
4/14/2017	11XX W 104TH ST	1.2	1.0	1.1	0.7		
8/23/2017	11XX W 19TH PL	2.2	4.2	6.2	2.7		
12/19/2017	121XX S MICHIGAN AVE	78	17	20	1.7		
	121XX S MICHIGAN AVE	Customer declined further testing					
2/28/2018	126XX S YALE AVE <b>SITE 1</b>	0.6	0.4	0.5	0.3	<0.3	
1/31/2018	126XX S YALE AVE <b>SITE 1</b>	1.4	0.3	0.3	<0.3		
1/18/2018	126XX S YALE AVE <b>SITE 2</b>	7.8	6.6	7.2	2.8		
2/14/2018	126XX S YALE AVE <b>SITE 2</b>	7.3	8.3	9.2	2.8	2.5	
12/14/2017	126XX S YALE AVE <b>SITE 2</b>	9.6	5.4	5.5	3.5		
10/26/2017	126XX S YALE AVE <b>SITE 2</b>	8.8	11	13	6.4		
10/12/2017	126XX S YALE AVE <b>SITE 2</b>	6.5	15	15	7.1		
11/7/2017	126XX S YALE AVE <b>SITE 2</b>	See Follow-Up Sequential Sampling Table for Results					
4/21/2017	12XX W 97TH PL <b>SITE 1</b>	2.0	2.5	2.6	1.1		
2/14/2018	12XX W 97TH PL <b>SITE 1</b>	2.9	3.1	4.8	1.3		
1/17/2018	12XX W 97TH PL <b>SITE 1</b>	3.3	2.8	4.3	1.4		
12/5/2017	12XX W 97TH PL <b>SITE 1</b>	3.0	4.2	6.6	1.7		
11/3/2017	12XX W 97TH PL <b>SITE 1</b>	2.8	4.9	8.1	2.1		
4/14/2017	12XX W 97TH PL <b>SITE 2</b>	1.2	1.2	2.5	0.7		
4/13/2017	12XX W 97TH PL <b>SITE 3</b>	4.3	6.5	6.5	1.4		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
10/26/2017	12XX W 97TH PL <b>SITE 3</b>	3.8	3.9	4.3	2.1	
4/21/2017	12XX W 97TH PL <b>SITE 4</b>	1.7	2.2	2.7	1.3	
4/17/2017	12XX W 97TH ST <b>SITE 1</b>	5.1	11	11	7.4	
2/7/2018	12XX W 97TH ST <b>SITE 2</b>	1.7	2.7	2.3	0.8	
1/16/2018	12XX W 97TH ST <b>SITE 2</b>	1.8	2.4	2.5	0.8	
12/14/2017	12XX W 97TH ST <b>SITE 2</b>	3.0	1.4	1.2	0.9	
4/14/2017	12XX W 97TH ST <b>SITE 2</b>	1.0	2.6	3.3	1.2	
10/26/2017	12XX W 97TH ST <b>SITE 2</b>	2.9	2.4	4.0	2.1	
11/8/2017	12XX W 97TH ST <b>SITE 3</b>	1.0	1.5	1.3	0.9	
4/13/2017	12XX W 97TH ST <b>SITE 3</b>	1.1	1.5	1.7	0.9	
4/14/2017	12XX W 97TH ST <b>SITE 4</b>	2.2	2.7	4.2	0.8	
2/23/2018	12XX W 97TH ST <b>SITE 4</b>	2.7	4.1	5.2	0.8	
12/14/2017	12XX W 97TH ST <b>SITE 4</b>	3.8	3.2	4.2	0.9	
1/25/2018	12XX W 97TH ST <b>SITE 4</b>	5.1	3.1	6.9	1.0	
11/2/2017	12XX W 97TH ST <b>SITE 4</b>	6.0	3.7	9.6	1.4	
4/14/2017	12XX W 97TH ST <b>SITE 5</b>	4.3	4.0	3.9	1.4	
10/27/2017	12XX W 97TH ST <b>SITE 5</b>	2.4	4.6	4.2	3.1	
5/12/2017	12XX W 97TH ST <b>SITE 6</b>	0.9	0.9	0.9	0.7	
10/27/2017	12XX W 97TH ST <b>SITE 6</b>	1.3	0.9	1.9	2.2	
2/7/2018	12XX W 97TH ST <b>SITE 7</b>	0.8	0.8	1.0	0.4	
1/16/2018	12XX W 97TH ST <b>SITE 7</b>	0.9	0.9	0.9	0.5	
6/1/2017	12XX W 97TH ST <b>SITE 7</b>	0.8	0.8	1.1	0.6	
12/6/2017	12XX W 97TH ST <b>SITE 7</b>	0.9	1.1	1.3	0.6	
10/26/2017	12XX W 97TH ST <b>SITE 7</b>	0.8	1.1	1.3	0.8	
4/19/2017	13XX W 97TH PL	2.0	1.5	1.6	1.0	
10/26/2017	13XX W 97TH PL	1.9	1.5	1.6	1.6	
4/14/2017	13XX W 97TH ST <b>SITE 1</b>	1.4	1.6	4.2	0.9	
10/26/2017	13XX W 97TH ST <b>SITE 1</b>	2.0	2.7	6.2	2.4	
1/19/2018	13XX W 97TH ST <b>SITE 2</b>	1.0	0.8	1.0	0.8	
2/7/2018	13XX W 97TH ST <b>SITE 2</b>	1.5	1.4	1.4	0.8	
4/14/2017	13XX W 97TH ST <b>SITE 2</b>	1.5	1.2	1.3	0.9	
12/14/2017	13XX W 97TH ST <b>SITE 2</b>	1.9	2.0	2.3	1.2	
11/3/2017	13XX W 97TH ST <b>SITE 2</b>	2.0	1.5	1.4	1.5	
2/7/2018	13XX W 97TH ST <b>SITE 3</b>	3.0	3.1	3.0	1.2	
4/14/2017	13XX W 97TH ST <b>SITE 3</b>	2.6	4.9	4.8	2.4	
12/6/2017	13XX W 97TH ST <b>SITE 3</b>	2.8	3.9	2.8	2.5	
1/25/2018	13XX W 97TH ST <b>SITE 3</b>	3.0	4.3	5.0	3.3	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
10/26/2017	13XX W 97TH ST <b>SITE 3</b>	3.6	7.0	7.1	5.4		
1/17/2018	13XX W 97TH ST <b>SITE 4</b>	2.3	6.9	0.9	0.5		
2/14/2018	13XX W 97TH ST <b>SITE 4</b>	1.3	1.0	1.4	0.6		
12/5/2017	13XX W 97TH ST <b>SITE 4</b>	1.7	3.7	1.6	0.7		
10/26/2017	13XX W 97TH ST <b>SITE 4</b>	2.6	2.6	2.2	0.9		
4/14/2017	13XX W 97TH ST <b>SITE 4</b>	2.5	2.2	2.3	1.2		
4/13/2017	13XX W 97TH ST <b>SITE 5</b>	7.2	4.5	4.3	1.7		
11/2/2017	13XX W 97TH ST <b>SITE 5</b>	3.7	5.2	6.0	2.6		
12/20/2017	14XX N ELK GROVE AVE	4.1	8.8	5.7	1.7	1.7	
8/29/2017	14XX N ELK GROVE AVE	1.7	7.5	3.7	2.1		
1/19/2018	14XX N OAKLEY BLVD	67	12	9.0	3.1		
12/8/2017	14XX N OAKLEY BLVD	7.4	19	13	4.1		
2/16/2018	14XX N OAKLEY BLVD	36	19	15	4.7		
10/11/2017	14XX N OAKLEY BLVD	12	17	12	5.0		
10/27/2017	14XX N OAKLEY BLVD	42	31	14	6.1		
11/11/2017	14XX N OAKLEY BLVD	See Follow-Up Sequential Sampling Table for Results					
4/17/2017	14XX W TOUHY AVE	0.9	3.3	6.4	0.3		
5/8/2017	14XX W TOUHY AVE	1.8	5.8	4.5	0.5		
9/13/2017	15XX N HONORE ST	3.5	14	9.4	5.0		
11/16/2017	15XX N LAWLER AVE	2.1	0.9	0.9	1.0		
11/3/2017	15XX N LAWLER AVE	1.4	1.4	1.5	1.3		
5/25/2017	15XX S ST LOUIS AVE	<0.3	<0.3	<0.3	<0.3		
10/25/2016	15XX S ST LOUIS AVE	<0.3	<0.3	<0.3	<0.3		
2/26/2018	16XX N NORMANDY AVE	7.3	15	19	4.9		
1/18/2018	16XX N NORMANDY AVE	11	19	22	5.7		
10/25/2017	16XX N NORMANDY AVE	5.3	12	16	6.0	6.1	
11/13/2017	16XX N NORMANDY AVE	19	17	21	6.6		
12/8/2017	16XX N NORMANDY AVE	10	17	21	6.8		
11/17/2017	16XX N NORMANDY AVE	See Follow-Up Sequential Sampling Table for Results					
11/22/2016	16XX W 37TH ST	3.2	6.1	8.8	1.9		
6/23/2017	18XX W 34TH ST <b>SITE 1</b>	3.3	3.5	5.9	2.3		
2/13/2018	18XX W 34TH ST <b>SITE 2</b>	1.0	1.0	1.1	0.6	0.5	
11/1/2017	18XX W 34TH ST <b>SITE 2</b>	1.5	1.6	1.7	0.9		
6/23/2017	18XX W 34TH ST <b>SITE 2</b>	2.2	1.7	1.9	0.9		
12/6/2017	18XX W 34TH ST <b>SITE 2</b>	1.9	2.2	1.9	0.9		
10/4/2017	18XX W 34TH ST <b>SITE 2</b>	2.1	2.1	2.1	1.1	1.2	
1/9/2018	18XX W 34TH ST <b>SITE 2</b>	1.6	1.4	1.5	1.6		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
9/15/2017	18XX W 34TH ST <b>SITE 2</b>	2.6	2.3	2.4	2.4		
6/23/2017	18XX W 34TH ST <b>SITE 3</b>	2.6	1.0	1.2	0.9		
9/15/2017	18XX W 34TH ST <b>SITE 3</b>	1.6	1.8	1.9	2.0		
6/23/2017	18XX W 34TH ST <b>SITE 4</b>	1.8	3.5	4.2	2.3		
9/22/2017	18XX W 34TH ST <b>SITE 4</b>	2.6	3.8	3.7	2.7		
2/13/2018	18XX W 34TH ST <b>SITE 5</b>	4.2	13	8.3	4.0		
12/12/2017	18XX W 34TH ST <b>SITE 5</b>	7.8	13	9.4	4.5		
1/9/2018	18XX W 34TH ST <b>SITE 5</b>	6.0	16	11	5.1		
11/9/2017	18XX W 34TH ST <b>SITE 5</b>	8.9	16	11	5.9		
6/23/2017	18XX W 34TH ST <b>SITE 5</b>	11	17	12	6.8		
9/22/2017	18XX W 34TH ST <b>SITE 5</b>	13	17	12	7.2		
10/31/2017	18XX W 34TH ST <b>SITE 5</b>	See Follow-Up Sequential Sampling Table for Results					
1/10/2018	18XX W 34TH ST <b>SITE 6</b>	2.6	0.8	0.8	0.7		
11/15/2017	18XX W 34TH ST <b>SITE 6</b>	1.0	0.9	0.9	0.7		
12/13/2017	18XX W 34TH ST <b>SITE 6</b>	1.8	1.1	1.1	0.7		
6/19/2017	18XX W 34TH ST <b>SITE 6</b>	2.0	0.9	0.8	1.5		
10/11/2017	18XX W 34TH ST <b>SITE 6</b>	1.9	1.5	1.2	1.5		
9/6/2017	18XX W 34TH ST <b>SITE 6</b>	1.8	2.6	3.5	1.7		
8/11/2017	18XX W 34TH ST <b>SITE 6</b>	1.6	1.5	1.8	2.2		
9/26/2017	18XX W 34TH ST <b>SITE 6</b>	See Follow-Up Sequential Sampling Table for Results					
2/12/2018	18XX W SUPERIOR ST	1.1	1.5	1.6	0.5		
12/21/2017	19XX W WINONA ST	<0.3	<0.3	<0.3	<0.3	<0.3	
9/20/2017	19XX W WINONA ST	<0.3	<0.3	<0.3	<0.3		
10/26/2016	1XX W 70TH ST <b>SITE 1</b>	1.6	1.8	1.9	0.7		
10/26/2016	1XX W 70TH ST <b>SITE 2</b>	0.9	0.8	1.5	0.6		
12/1/2017	20XX W CHASE AVE	9.3	14	19	2.6		
1/5/2018	20XX W CHASE AVE	See Follow-Up Sequential Sampling Table for Results					
9/8/2016	21XX N AVERS AVE	6.8	10	11	7.4		
1/11/2017	21XX N AVERS AVE	6.0	8.8	12	8.7		
3/15/2017	21XX N MAPLEWOOD AVE <b>SITE 1</b>	4.2	6.5	5.8	2.5		
10/27/2016	21XX N MAPLEWOOD AVE <b>SITE 1</b>	4.3	5.6	5.3	4.1		
3/15/2017	21XX N MAPLEWOOD AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
11/3/2016	21XX N MAPLEWOOD AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
11/3/2016	21XX N MAPLEWOOD AVE <b>SITE 3</b>	2.2	0.7	0.7	0.6		
3/16/2017	21XX N MAPLEWOOD AVE <b>SITE 3</b>	0.7	0.7	1.6	0.7		
2/8/2017	21XX N SPRINGFIELD AVE <b>SITE 1</b>	1.1	0.6	0.6	0.4		
1/11/2017	21XX N SPRINGFIELD AVE <b>SITE 1</b>	1.1	0.8	0.9	0.5		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
3/13/2017	21XX N SPRINGFIELD AVE <b>SITE 1</b>	1.3	0.9	0.9	0.5		
4/4/2017	21XX N SPRINGFIELD AVE <b>SITE 1</b>	0.8	0.8	0.8	0.7		
5/3/2017	21XX N SPRINGFIELD AVE <b>SITE 1</b>	0.9	1.0	1.1	0.8		
6/7/2017	21XX N SPRINGFIELD AVE <b>SITE 1</b>	1.4	1.5	1.7	1.2	1.2	
9/7/2016	21XX N SPRINGFIELD AVE <b>SITE 1</b>	2.0	1.7	1.6	1.5		
9/8/2016	21XX N SPRINGFIELD AVE <b>SITE 2</b>	0.8	0.6	0.6	0.5		
6/8/2017	21XX W 54TH PL	1.8	1.8	2.6	1.0		
12/28/2017	21XX W 68TH ST	3.2	3.8	4.0	1.3		
2/2/2018	21XX W 68TH ST	7.3	7.1	6.6	1.4		
1/18/2017	21XX W AGATITE AVE <b>SITE 1</b>	1.1	1.0	1.0	0.5		
10/27/2016	21XX W AGATITE AVE <b>SITE 1</b>	1.7	2.2	1.9	1.0	0.9	
1/18/2017	21XX W AGATITE AVE <b>SITE 2</b>	6.8	12	9.0	2.1		
11/2/2016	21XX W AGATITE AVE <b>SITE 2</b>	7.3	22	16	3.4		
	21XX W AGATITE AVE <b>SITE 2</b>	Customer declined further testing					
3/23/2017	21XX W GRACE ST	5.2	4.3	4.0	2.7		
10/27/2016	21XX W SUNNYSIDE AVE <b>SITE 1</b>	4.3	5.5	6.4	3.8		
1/20/2017	21XX W SUNNYSIDE AVE <b>SITE 1</b>	3.0	4.2	7.9	5.0		
1/20/2017	21XX W SUNNYSIDE AVE <b>SITE 2</b>	2.1	4.0	7.3	2.2		
10/27/2016	21XX W SUNNYSIDE AVE <b>SITE 2</b>	4.8	5.1	9.1	4.2		
3/15/2017	22XX N MAPLEWOOD AVE	2.7	2.9	2.4	1.6		
4/12/2017	22XX N MAPLEWOOD AVE	4.2	10	6.2	2.1		
5/17/2017	22XX N MAPLEWOOD AVE	4.5	12	7.9	2.8		
10/27/2016	22XX N MAPLEWOOD AVE	3.2	11	7.3	3.2		
6/21/2017	22XX N MAPLEWOOD AVE	3.8	13	8.5	3.4		
7/12/2017	22XX N MAPLEWOOD AVE	3.8	11	8.2	3.7		
8/16/2017	22XX N MAPLEWOOD AVE	5.3	11	8.0	4.5		
2/26/2018	22XX S KOSTNER AVE	0.8	0.7	2.2	0.5		
1/23/2018	22XX S KOSTNER AVE	0.7	1.4	6.4	0.6		
3/21/2017	23XX N MAPLEWOOD AVE	2.7	7.2	7.8	1.5		
10/27/2016	23XX N MAPLEWOOD AVE	2.8	5.7	6.1	2.8		
12/21/2016	23XX W JARVIS AVE	5.3	5.3	7.4	1.2	1.3	
9/15/2016	23XX W JARVIS AVE	6.1	10	3.1	1.8		
9/21/2017	24XX N CAMPBELL AVE <b>SITE 1</b>	2.3	2.4	1.8	1.3		
9/25/2017	24XX N CAMPBELL AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
3/22/2017	24XX N FRANCISCO AVE <b>SITE 1</b>	2.8	6.3	4.5	1.4		
12/13/2017	24XX N FRANCISCO AVE <b>SITE 1</b>	4.4	10	7.2	2.0		
11/15/2017	24XX N FRANCISCO AVE <b>SITE 1</b>	8.3	5.9	7.5	2.2		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
9/26/2017	24XX N FRANCISCO AVE <b>SITE 1</b>	3.3	3.5	5.4	2.8	
10/18/2017	24XX N FRANCISCO AVE <b>SITE 1</b>	4.4	5.9	6.2	2.8	2.8
7/11/2017	24XX N FRANCISCO AVE <b>SITE 1</b>	4.9	8.5	6.3	3.1	
8/23/2017	24XX N FRANCISCO AVE <b>SITE 1</b>	4.7	6.7	6.8	9.2	
12/13/2017	24XX N FRANCISCO AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
11/13/2017	24XX N FRANCISCO AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
10/25/2017	24XX N FRANCISCO AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
9/29/2017	24XX N FRANCISCO AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
8/16/2017	24XX N FRANCISCO AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
7/18/2017	24XX N FRANCISCO AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
4/3/2017	24XX N FRANCISCO AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
7/11/2017	24XX N FRANCISCO AVE <b>SITE 3</b>	9.4	11	9.8	4.2	4.0
4/3/2017	24XX N FRANCISCO AVE <b>SITE 3</b>	7.0	37	37	4.9	
	24XX N FRANCISCO AVE <b>SITE 3</b>	Customer declined further testing				
3/16/2017	24XX N HAMLIN AVE**	15	3.8	4.1	1.8	
4/18/2017	24XX N HAMLIN AVE**	25	19	270	2.9	
4/4/2017	24XX N HAMLIN AVE**	See Follow-Up Sequential Sampling Table for Results				
4/7/2017	24XX N TALMAN AVE <b>SITE 1</b>	4.2	1.3	1.3	1.1	
4/6/2017	24XX N TALMAN AVE <b>SITE 1</b>	5.1	11	9.7	1.9	1.9
7/18/2017	24XX N TALMAN AVE <b>SITE 1</b>	4.4	7.7	9.5	3.2	
3/28/2017	24XX N TALMAN AVE <b>SITE 2</b>	8.6	23	18	4.6	
7/18/2017	24XX N TALMAN AVE <b>SITE 2</b>	14	26	20	7.7	
	24XX N TALMAN AVE <b>SITE 2</b>	Customer declined further testing				
9/21/2017	25XX N CAMPBELL AVE	<0.3	<0.3	<0.3	<0.3	
5/17/2017	25XX N KEELER AVE	4.2	6.0	20	3.2	
10/19/2016	25XX N KEELER AVE	3.6	5.3	25	7.0	
11/2/2016	25XX N KEELER AVE	See Follow-Up Sequential Sampling Table for Results				
4/19/2017	25XX N TALMAN AVE	0.8	0.7	0.9	0.5	0.5
7/19/2017	25XX N TALMAN AVE	0.6	0.8	0.8	0.7	
4/6/2017	25XX N WASHTENAW AVE	2.1	2.2	1.8	1.4	
7/19/2017	25XX N WASHTENAW AVE	2.4	2.9	2.8	2.6	
2/23/2018	25XX W 110TH ST	2.3	3.4	4.5	0.7	
3/14/2017	25XX W SHAKESPEARE AVE	1.7	1.3	1.7	0.9	
4/12/2017	25XX W SHAKESPEARE AVE	1.6	1.6	2.7	1.1	1.2
6/14/2017	25XX W SHAKESPEARE AVE	1.4	1.4	1.5	1.3	
5/17/2017	25XX W SHAKESPEARE AVE	1.6	1.4	1.9	1.4	
11/3/2016	25XX W SHAKESPEARE AVE	2.8	2.5	4.4	1.6	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
7/12/2017	25XX W SHAKESPEARE AVE	1.7	1.2	1.7	1.7		
8/16/2017	25XX W SHAKESPEARE AVE	1.8	1.7	1.9	1.9		
6/19/2017	26XX N DRAKE AVE <b>SITE 1</b>	5.9	5.9	4.9	4.0		
6/19/2017	26XX N DRAKE AVE <b>SITE 2</b> <sup>^</sup>	4.6	22	16	5.6		
8/4/2017	26XX N DRAKE AVE <b>SITE 2</b> <sup>^</sup>	See Follow-Up Sequential Sampling Table for Results					
5/18/2017	26XX N WHIPPLE ST	1.9	5.5	4.3	1.8		
8/4/2017	26XX N WHIPPLE ST	1.9	4.9	3.9	2.2		
9/30/2016	26XX S SACRAMENTO AVE	2.2	0.9	0.7	0.5	0.6	
2/10/2017	26XX S SACRAMENTO AVE	1.3	<0.3	<0.3	<0.3		
3/28/2017	26XX W ALTGELD ST	2.2	2.2	1.3	0.7		
7/21/2017	26XX W ALTGELD ST	4.2	4.4	2.4	1.5		
4/10/2017	26XX W FULLERTON AVE	6.8	2.8	3.6	1.6	1.6	
7/19/2017	26XX W FULLERTON AVE	5.1	2.7	3.3	2.1		
3/28/2017	26XX W HOMER ST	13	3.4	2.9	1.8		
4/12/2017	26XX W HOMER ST	4.1	7.0	7.0	2.0		
6/19/2017	27XX N DRAKE AVE <b>SITE 1</b>	14	10	10	3.1		
8/15/2017	27XX N DRAKE AVE <b>SITE 1</b>	7.5	7.2	7.1	4.0		
1/10/2018	27XX N DRAKE AVE <b>SITE 2</b>	2.6	0.8	0.8	0.7		
11/15/2017	27XX N DRAKE AVE <b>SITE 2</b>	1.0	0.9	0.9	0.7		
12/13/2017	27XX N DRAKE AVE <b>SITE 2</b>	1.8	1.1	1.1	0.7		
6/19/2017	27XX N DRAKE AVE <b>SITE 2</b>	2.0	0.9	0.8	1.5		
10/11/2017	27XX N DRAKE AVE <b>SITE 2</b>	1.9	1.5	1.2	1.5		
9/6/2017	27XX N DRAKE AVE <b>SITE 2</b>	1.8	2.6	3.5	1.7		
8/11/2017	27XX N DRAKE AVE <b>SITE 2</b>	1.6	1.5	1.8	2.2		
1/10/2018	27XX N WHIPPLE ST <b>SITE 1</b>	0.5	0.4	0.4	0.3		
12/13/2017	27XX N WHIPPLE ST <b>SITE 1</b>	0.5	0.4	0.4	0.4		
11/15/2017	27XX N WHIPPLE ST <b>SITE 1</b>	0.8	0.6	0.5	0.6		
5/18/2017	27XX N WHIPPLE ST <b>SITE 1</b>	1.5	1.4	2.0	0.9		
10/11/2017	27XX N WHIPPLE ST <b>SITE 1</b>	1.0	0.9	0.8	1.0		
9/13/2017	27XX N WHIPPLE ST <b>SITE 1</b>	1.2	1.2	1.3	1.3		
8/11/2017	27XX N WHIPPLE ST <b>SITE 1</b>	1.4	1.6	1.8	1.4		
5/19/2017	27XX N WHIPPLE ST <b>SITE 2</b>	1.0	1.4	1.5	2.9		
8/25/2017	27XX N WHIPPLE ST <b>SITE 2</b>	1.0	1.4	1.3	3.0		
8/3/2017	27XX N WHIPPLE ST <b>SITE 3</b>	<0.3	<0.3	<0.3	0.5		
5/19/2017	27XX N WHIPPLE ST <b>SITE 3</b>	<0.3	<0.3	<0.3	<0.3		
5/19/2017	27XX N WHIPPLE ST <b>SITE 4</b>	2.9	3.7	7.4	1.7		
8/4/2017	27XX N WHIPPLE ST <b>SITE 4</b>	3.7	4.4	8.2	2.5		

all results are shown in PPB (Parts per Billion)



Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
12/13/2017	27XX N WHIPPLE ST <b>SITE 5</b>	11	13	10	2.2	
1/10/2018	27XX N WHIPPLE ST <b>SITE 5</b>	12	14	11	2.2	
11/15/2017	27XX N WHIPPLE ST <b>SITE 5</b>	10	13	9.7	2.5	
5/18/2017	27XX N WHIPPLE ST <b>SITE 5</b>	13	14	13	3.1	
10/11/2017	27XX N WHIPPLE ST <b>SITE 5</b>	9.2	12	10	3.6	3.5
9/6/2017	27XX N WHIPPLE ST <b>SITE 5</b>	12	14	13	4.4	
8/4/2017	27XX N WHIPPLE ST <b>SITE 5</b>	13	15	13	4.8	
	27XX N WHIPPLE ST <b>SITE 5</b>	Customer declined further testing				
5/30/2017	27XX N WHIPPLE ST <b>SITE 6</b>	7.3	9.1	9.5	3.8	
8/8/2017	27XX N WHIPPLE ST <b>SITE 6</b>	18	14	8.6	4.8	4.9
	27XX N WHIPPLE ST <b>SITE 6</b>	Customer declined further testing				
8/16/2017	28XX N CHRISTIANA AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
7/12/2017	28XX N CHRISTIANA AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
6/14/2017	28XX N CHRISTIANA AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	<0.3
5/17/2017	28XX N CHRISTIANA AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	<0.3
4/12/2017	28XX N CHRISTIANA AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
3/22/2017	28XX N CHRISTIANA AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
9/30/2016	28XX N CHRISTIANA AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
3/15/2017	28XX N CHRISTIANA AVE <b>SITE 2</b>	5.7	8.0	8.1	2.7	
9/30/2016	28XX N CHRISTIANA AVE <b>SITE 2</b>	5.6	11	11	5.2	
3/15/2017	28XX N CHRISTIANA AVE <b>SITE 3</b>	12	16	12	4.6	
9/30/2016	28XX N CHRISTIANA AVE <b>SITE 3</b>	19	15	13	8.4	
4/7/2017	28XX N CHRISTIANA AVE <b>SITE 3</b>	See Follow-Up Sequential Sampling Table for Results				
2/24/2017	28XX W 40TH ST**	34	51	20	1.3	
10/19/2016	28XX W 40TH ST**	2.2	1.9	1.9	1.8	
10/25/2016	28XX W 40TH ST**	3.2	2.6	2.8	2.0	
3/3/2017	28XX W 40TH ST**	See Follow-Up Sequential Sampling Table for Results				
2/12/2018	28XX W FLOURNOY ST	2.5	2.8	2.6	1.0	
12/12/2017	29XX N GRESHAM AVE	0.9	0.6	0.6	0.4	
12/6/2017	29XX N MOBILE AVE	9.9	9.7	8.9	3.4	
10/25/2017	29XX N MOBILE AVE	8.5	8.4	8.6	3.6	
2/24/2017	29XX W 40TH ST	3.5	2.2	1.9	1.4	
10/19/2016	29XX W 40TH ST	4.5	4.9	4.1	2.7	
2/16/2018	29XX W WILSON AVE	2.4	5.3	4.7	1.6	
7/26/2017	29XX W WILSON AVE	9.3	13	12	3.9	
10/10/2017	2XX W 107TH ST	3.0	3.7	4.1	3.2	
2/8/2018	30XX N KIMBALL AVE	1.6	4.0	1.7	0.8	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
6/22/2017	30XX S HOMAN AVE	0.7	0.7	1.7	0.5		
3/21/2017	30XX S HOMAN AVE	0.5	0.5	1.3	<0.3		
12/22/2017	30XX W 41ST ST	3.6	6.8	6.6	1.8		
3/15/2017	30XX W DIVERSEY AVE <b>SITE 1</b>	5.5	7.0	8.0	3.0		
10/6/2016	30XX W DIVERSEY AVE <b>SITE 1</b>	7.8	8.3	12	5.3		
5/18/2017	30XX W DIVERSEY AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
4/12/2017	30XX W DIVERSEY AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	<0.3	
3/14/2017	30XX W DIVERSEY AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
10/6/2016	30XX W DIVERSEY AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	<0.3	
2/22/2018	30XX W WILSON AVE	1.5	2.9	6.0	0.9		
8/9/2017	30XX W WILSON AVE	1.7	3.8	6.1	1.8		
6/29/2017	31XX N RIDGEWAY AVE <b>SITE 1</b>	3.8	6.1	6.0	3.9		
8/18/2017	31XX N RIDGEWAY AVE <b>SITE 1</b>	5.5	13	11	5.4		
1/10/2018	31XX N RIDGEWAY AVE <b>SITE 2</b>	2.4	9.8	8.0	1.5		
12/6/2017	31XX N RIDGEWAY AVE <b>SITE 2</b>	8.1	8.6	5.6	3.0		
10/11/2017	31XX N RIDGEWAY AVE <b>SITE 2</b>	5.8	7.8	5.1	3.1		
6/21/2017	31XX N RIDGEWAY AVE <b>SITE 2</b>	7.9	6.2	3.4	5.6	5.3	
9/15/2017	31XX N RIDGEWAY AVE <b>SITE 2</b>	110	43	33	6.0		
11/15/2017	31XX N RIDGEWAY AVE <b>SITE 2</b>	4.5	7.4	9.6	6.4		
8/18/2017	31XX N RIDGEWAY AVE <b>SITE 2</b>	6.8	8.8	6.1	9.5		
	31XX N RIDGEWAY AVE <b>SITE 2</b>	Customer declined further testing					
4/5/2017	31XX N RUTHERFORD AVE	2.4	3.9	3.8	1.3		
4/7/2017	32XX N NAGLE AVE <b>SITE 1</b>	0.5	0.6	0.6	0.5		
6/28/2017	32XX N NAGLE AVE <b>SITE 1</b>	2.0	2.4	2.2	1.3	1.3	
4/10/2017	32XX N NAGLE AVE <b>SITE 2</b>	4.9	6.6	6.7	3.4		
9/21/2017	32XX N NAGLE AVE <b>SITE 2</b>	4.7	7.2	7.4	5.5		
10/19/2017	32XX N NAGLE AVE <b>SITE 2</b>	4.1	8.0	8.3	5.5		
6/27/2017	32XX N NAGLE AVE <b>SITE 2</b>	3.7	6.6	8.1	6.0		
8/24/2017	32XX N NAGLE AVE <b>SITE 2</b>	4.6	7.1	8.2	6.0		
12/8/2017	32XX N NAGLE AVE <b>SITE 2</b>	5.0	10	8.3	7.2		
11/16/2017	32XX N NAGLE AVE <b>SITE 2</b>	4.6	7.4	7.7	7.8		
4/6/2017	32XX N NAGLE AVE <b>SITE 3</b>	2.9	6.1	7.3	2.2		
11/15/2017	32XX N NAGLE AVE <b>SITE 3</b>	4.2	7.1	10	3.0		
10/19/2017	32XX N NAGLE AVE <b>SITE 3</b>	3.7	7.5	11	4.0		
9/21/2017	32XX N NAGLE AVE <b>SITE 3</b>	8.1	9.8	12	4.6		
7/27/2017	32XX N NAGLE AVE <b>SITE 3</b>	7.2	5.0	7.1	5.1		
6/27/2017	32XX N NAGLE AVE <b>SITE 3</b>	4.5	5.6	11	7.6		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
8/29/2017	32XX N NAGLE AVE <b>SITE 3</b>	5.0	9.2	14	21		
9/19/2017	32XX N NAGLE AVE <b>SITE 3</b>	See Follow-Up Sequential Sampling Table for Results					
10/30/2017	32XX N NATCHEZ AVE	2.2	2.4	4.1	2.2		
2/1/2018	32XX S GREEN ST	2.1	3.7	2.3	1.4		
5/17/2017	32XX W DIVERSEY AVE	3.1	6.1	3.3	1.2		
4/13/2017	32XX W DIVERSEY AVE	1.4	1.7	2.2	1.4		
3/14/2017	32XX W DIVERSEY AVE	1.4	1.8	2.4	1.6		
6/14/2017	32XX W DIVERSEY AVE	1.7	4.6	7.1	1.6		
7/12/2017	32XX W DIVERSEY AVE	2.1	2.0	2.1	1.7		
9/30/2016	32XX W DIVERSEY AVE	4.5	6.2	4.5	2.0		
8/16/2017	32XX W DIVERSEY AVE	2.9	6.9	5.9	2.1		
9/7/2016	32XX W THOMAS ST	10	25	73	9.8		
8/2/2017	32XX W THOMAS ST	See Follow-Up Sequential Sampling Table for Results					
4/6/2017	33XX N NAGLE AVE	2.0	2.2	2.2	1.0		
3/23/2017	33XX N NEVA AVE	1.7	3.0	3.0	0.6		
4/10/2017	33XX N NEVA AVE	2.7	3.5	2.6	1.0		
2/5/2018	33XX N RIDGEWAY AVE	3.0	9.6	9.3	1.8		
1/17/2018	33XX N RIDGEWAY AVE	4.3	8.1	6.4	2.0		
2/22/2018	33XX S ABERDEEN ST	3.2	11	7.2	2.4		
2/2/2018	33XX W 55TH ST	1.9	0.4	0.7	0.3		
8/15/2017	33XX W 55TH ST	<0.3	<0.3	<0.3	<0.3		
2/2/2018	33XX W 59TH ST <b>SITE 1</b>	2.2	0.8	0.8	0.4		
8/2/2017	33XX W 59TH ST <b>SITE 1</b>	1.2	1.2	1.4	0.9		
8/10/2017	33XX W 59TH ST <b>SITE 2</b>	0.7	0.6	0.8	0.4		
2/2/2018	33XX W 59TH ST <b>SITE 2</b>	1.0	0.6	0.8	<0.3		
6/2/2017	34XX N KOSTNER AVE <b>SITE 1</b>	4.2	4.4	4.0	2.1		
8/31/2017	34XX N KOSTNER AVE <b>SITE 1</b>	4.4	6.5	7.6	3.2	3.1	
6/2/2017	34XX N KOSTNER AVE <b>SITE 2</b>	10	2.0	9.9	0.9	0.9	
9/1/2017	34XX N KOSTNER AVE <b>SITE 2</b>	11	3.3	3.5	1.0		
6/2/2017	34XX N KOSTNER AVE <b>SITE 3</b>	3.3	5.8	8.5	1.7		
8/31/2017	34XX N KOSTNER AVE <b>SITE 3</b>	3.5	5.0	7.9	2.7		
6/2/2017	34XX N KOSTNER AVE <b>SITE 4</b>	1.6	1.9	2.1	0.9		
10/9/2017	34XX N KOSTNER AVE <b>SITE 4</b>	1.9	4.5	3.0	1.3		
9/7/2017	34XX N KOSTNER AVE <b>SITE 4</b>	2.2	3.4	4.5	1.7		
7/6/2017	34XX S MARSHFIELD AVE <b>SITE 1</b>	5.8	9.6	8.1	2.8	2.6	
2/13/2018	34XX S MARSHFIELD AVE <b>SITE 2</b>	5.6	15	14	3.4		
1/9/2018	34XX S MARSHFIELD AVE <b>SITE 2</b>	5.7	15	14	3.5		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
11/1/2017	34XX S MARSHFIELD AVE <b>SITE 2</b>	7.3	18	17	6.4		
12/6/2017	34XX S MARSHFIELD AVE <b>SITE 2</b>	9.5	18	25	6.5		
6/22/2017	34XX S MARSHFIELD AVE <b>SITE 2</b>	9.0	21	20	8.2		
10/13/2017	34XX S MARSHFIELD AVE <b>SITE 2</b>	8.1	21	21	8.7		
9/15/2017	34XX S MARSHFIELD AVE <b>SITE 2</b>	8.4	21	21	11		
7/10/2017	34XX S MARSHFIELD AVE <b>SITE 2</b>	See Follow-Up Sequential Sampling Table for Results					
11/1/2017	34XX S MARSHFIELD AVE <b>SITE 3</b>	6.7	5.0	4.5	3.2		
6/28/2017	34XX S MARSHFIELD AVE <b>SITE 3</b>	7.7	6.4	5.4	3.2		
12/6/2017	34XX S MARSHFIELD AVE <b>SITE 3</b>	7.4	6.1	5.1	3.4		
10/4/2017	34XX S MARSHFIELD AVE <b>SITE 3</b>	17	5.1	4.4	3.6		
9/15/2017	34XX S MARSHFIELD AVE <b>SITE 3</b>	10	6.0	5.4	4.7		
	34XX S MARSHFIELD AVE <b>SITE 3</b>	Customer declined further testing					
10/31/2017	34XX W 12TH PL <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3		
9/29/2017	34XX W 12TH PL <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3		
8/30/2017	34XX W 12TH PL <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3		
8/10/2017	34XX W 12TH PL <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3		
6/29/2017	34XX W 12TH PL <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3		
5/19/2017	34XX W 12TH PL <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3		
10/25/2016	34XX W 12TH PL <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3		
10/25/2016	34XX W 12TH PL <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
1/22/2018	34XX W 73RD PL	6.0	4.3	7.4	1.3		
2/6/2018	34XX W 73RD PL	4.9	8.0	5.8	3.1		
4/10/2017	35XX N NAGLE AVE <b>SITE 1</b>	1.8	4.3	3.2	0.9		
4/7/2017	35XX N NAGLE AVE <b>SITE 2</b>	<0.3	<0.3	0.3	<0.3		
11/16/2017	35XX N NAGLE AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
10/19/2017	35XX N NAGLE AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
9/21/2017	35XX N NAGLE AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
8/24/2017	35XX N NAGLE AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
7/27/2017	35XX N NAGLE AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3		
6/27/2017	35XX N NAGLE AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	<0.3	
3/23/2017	35XX S PAULINA ST	0.5	<0.3	<0.3	<0.3		
11/30/2016	35XX S PAULINA ST	0.8	<0.3	<0.3	<0.3		
5/25/2017	35XX W 12TH PL	<0.3	<0.3	<0.3	<0.3		
10/31/2016	35XX W 12TH PL	<0.3	<0.3	<0.3	<0.3		
1/10/2018	36XX N DRAKE AVE	2.3	0.8	0.7	0.7		
12/13/2017	36XX N DRAKE AVE	2.9	1.0	0.8	0.8		
11/15/2017	36XX N DRAKE AVE	3.6	1.1	1.0	1.0	0.9	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
10/11/2017	36XX N DRAKE AVE	6.1	2.1	2.0	1.9		
5/11/2017	36XX N DRAKE AVE	2.4	1.8	1.7	2.0		
8/24/2017	36XX N DRAKE AVE	2.0	1.8	4.2	2.4		
9/12/2017	36XX N DRAKE AVE	2.4	4.6	5.1	5.0		
5/9/2017	36XX N WHIPPLE ST	1.2	2.1	2.4	1.1		
9/20/2017	36XX N WHIPPLE ST	2.9	2.9	3.0	2.4		
11/22/2016	36XX S PAULINA ST <b>SITE 1</b>	2.2	3.1	2.1	1.8		
3/10/2017	36XX S PAULINA ST <b>SITE 1</b>	3.3	3.4	2.3	1.8		
3/10/2017	36XX S PAULINA ST <b>SITE 2</b>	1.1	0.5	0.5	0.4		
4/13/2017	36XX S PAULINA ST <b>SITE 2</b>	3.3	0.7	0.7	0.5		
11/22/2016	36XX S PAULINA ST <b>SITE 2</b>	2.9	0.8	0.7	0.6		
3/10/2017	36XX S PAULINA ST <b>SITE 3</b>	4.6	10	6.6	1.8		
4/13/2017	36XX S PAULINA ST <b>SITE 3</b>	9.1	8.9	4.7	2.1		
11/22/2016	36XX S PAULINA ST <b>SITE 3</b>	2.7	4.4	4.5	2.3		
5/23/2017	36XX S PAULINA ST <b>SITE 3</b>	270	12	7.9	2.9		
7/13/2017	36XX S PAULINA ST <b>SITE 3</b>	3.8	6.2	7.4	3.0		
6/15/2017	36XX S PAULINA ST <b>SITE 3</b>	4.1	4.7	4.8	3.1	3.2	
8/17/2017	36XX S PAULINA ST <b>SITE 3</b>	4.0	4.6	4.4	3.5		
6/7/2017	36XX S PAULINA ST <b>SITE 3</b>	See Follow-Up Sequential Sampling Table for Results					
10/26/2016	36XX W 57TH PL <b>SITE 1</b>	<0.3	<0.3	0.3	0.3		
3/17/2017	36XX W 57TH PL <b>SITE 2</b>	2.3	3.2	3.4	1.3		
4/13/2017	36XX W 57TH PL <b>SITE 2</b>	2.7	3.5	3.6	1.4		
10/26/2016	36XX W 57TH PL <b>SITE 2</b>	2.1	3.5	2.9	1.9		
5/18/2017	36XX W 57TH PL <b>SITE 2</b>	3.2	7.8	6.7	2.0		
7/20/2017	36XX W 57TH PL <b>SITE 2</b>	3.3	4.9	7.3	2.8		
6/22/2017	36XX W 57TH PL <b>SITE 2</b>	4.0	5.6	9.0	2.9		
8/17/2017	36XX W 57TH PL <b>SITE 2</b>	5.4	9.0	8.7	3.6		
3/21/2017	36XX W 57TH PL <b>SITE 3</b>	14	1.8	2.3	0.9		
10/26/2016	36XX W 57TH PL <b>SITE 3</b>	2.8	4.9	7.5	2.1		
5/10/2017	37XX N DRAKE AVE <b>SITE 1</b>	0.9	1.1	1.2	0.7	0.7	
8/24/2017	37XX N DRAKE AVE <b>SITE 1</b>	1.6	2.3	2.4	2.0		
5/11/2017	37XX N DRAKE AVE <b>SITE 2</b>	2.2	4.0	2.5	1.2		
8/24/2017	37XX N DRAKE AVE <b>SITE 2</b>	2.9	6.3	4.3	2.5		
5/11/2017	37XX N DRAKE AVE <b>SITE 3</b>	2.1	3.8	3.3	1.7		
8/24/2017	37XX N DRAKE AVE <b>SITE 3</b>	4.4	6.0	4.9	4.4		
5/11/2017	37XX N DRAKE AVE <b>SITE 4</b>	0.7	2.1	2.2	0.6		
8/24/2017	37XX N DRAKE AVE <b>SITE 4</b>	1.2	2.0	2.2	1.2		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
12/7/2017	37XX N GREENVIEW AVE <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
12/6/2017	37XX N GREENVIEW AVE <b>SITE 2</b>	4.1	8.0	6.7	2.1	2.1
5/4/2017	37XX N WHIPPLE ST <b>SITE 1</b>	2.1	1.9	1.5	1.0	
9/22/2017	37XX N WHIPPLE ST <b>SITE 1</b>	5.1	5.3	4.0	2.2	
2/8/2018	37XX N WHIPPLE ST <b>SITE 2</b>	6.3	8.2	8.3	2.1	
5/4/2017	37XX N WHIPPLE ST <b>SITE 2</b>	5.8	7.0	6.9	2.6	
1/11/2018	37XX N WHIPPLE ST <b>SITE 2</b>	7.1	8.3	8.0	2.7	
12/7/2017	37XX N WHIPPLE ST <b>SITE 2</b>	8.3	13	14	3.4	
11/2/2017	37XX N WHIPPLE ST <b>SITE 2</b>	7.7	9.9	14	4.6	4.6
9/22/2017	37XX N WHIPPLE ST <b>SITE 2</b>	7.3	8.3	10	4.8	
10/5/2017	37XX N WHIPPLE ST <b>SITE 2</b>	7.4	8.5	10	5.1	
5/5/2017	37XX N WHIPPLE ST <b>SITE 3</b>	2.7	3.9	4.7	1.6	
9/19/2017	37XX N WHIPPLE ST <b>SITE 3</b>	3.7	6.7	7.0	7.3	
5/5/2017	37XX N WHIPPLE ST <b>SITE 4</b>	1.1	1.9	1.5	0.3	
1/11/2018	37XX N WHIPPLE ST <b>SITE 4</b>	0.9	1.0	2.8	0.3	
12/12/2017	37XX N WHIPPLE ST <b>SITE 4</b>	2.2	1.2	1.5	0.4	
11/2/2017	37XX N WHIPPLE ST <b>SITE 4</b>	0.7	1.3	2.0	0.4	
9/19/2017	37XX N WHIPPLE ST <b>SITE 4</b>	1.2	0.8	0.9	0.5	
10/5/2017	37XX N WHIPPLE ST <b>SITE 4</b>	0.6	1.5	0.9	0.5	
2/8/2018	37XX N WHIPPLE ST <b>SITE 4</b>	1.1	0.6	0.4	<0.3	
2/8/2018	37XX N WHIPPLE ST <b>SITE 5</b>	2.1	0.8	0.9	0.6	
1/11/2018	37XX N WHIPPLE ST <b>SITE 5</b>	1.4	0.7	0.8	0.7	
12/7/2017	37XX N WHIPPLE ST <b>SITE 5</b>	2.6	1.5	1.5	1.2	
11/9/2017	37XX N WHIPPLE ST <b>SITE 5</b>	3.7	1.4	1.5	1.3	1.4
5/9/2017	37XX N WHIPPLE ST <b>SITE 5</b>	2.2	2.0	2.0	1.4	1.2
10/25/2017	37XX N WHIPPLE ST <b>SITE 5</b>	1.8	1.9	1.8	1.7	
9/19/2017	37XX N WHIPPLE ST <b>SITE 5</b>	3.2	2.5	2.4	2.4	
5/5/2017	37XX N WHIPPLE ST <b>SITE 6</b>	3.7	20	13	2.2	
10/6/2017	37XX N WHIPPLE ST <b>SITE 6</b>	6.1	7.1	5.7	3.1	
5/27/2017	37XX N WHIPPLE ST <b>SITE 6</b>	See Follow-Up Sequential Sampling Table for Results				
4/25/2017	37XX S MICHIGAN AVE	3.5	5.3	4.8	1.5	
10/26/2016	37XX W 57TH PL <b>SITE 1</b>	0.8	0.4	0.5	0.4	
3/17/2017	37XX W 57TH PL <b>SITE 1</b>	0.7	1.1	0.5	0.5	
3/17/2017	37XX W 57TH PL <b>SITE 2</b>	0.5	0.5	0.7	0.4	
10/26/2016	37XX W 57TH PL <b>SITE 2</b>	0.5	0.5	0.7	0.7	
6/13/2017	37XX W EDDY ST	1.3	2.3	2.0	0.8	
7/13/2017	37XX W EDDY ST	1.4	3.1	2.2	0.9	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
7/11/2017	37XX W FERDINAND ST	6.1	5.2	4.4	3.1	
10/25/2016	37XX W FERDINAND ST	5.9	5.5	4.8	3.3	
8/23/2017	37XX W FERDINAND ST	4.3	4.4	4.1	3.6	3.6
11/20/2017	38XX N ALTA VISTA TER	1.7	1.5	4.1	0.5	0.4
8/23/2017	38XX N DRAKE AVE	<0.3	<0.3	<0.3	0.3	
5/10/2017	38XX N DRAKE AVE	<0.3	<0.3	<0.3	<0.3	
2/13/2018	38XX N KEDVALE AVE	3.7	4.4	4.8	1.7	
1/10/2018	38XX N KEDVALE AVE	4.7	7.0	7.7	2.0	
5/30/2017	38XX N KEDVALE AVE	5.4	4.7	8.8	2.2	
12/19/2017	38XX N KEDVALE AVE	5.9	5.5	8.4	2.5	
11/28/2017	38XX N KEDVALE AVE	6.0	5.0	8.9	2.7	2.7
10/30/2017	38XX N KEDVALE AVE	6.7	12	14	3.7	
9/28/2017	38XX N KEDVALE AVE	7.0	8.4	11	4.4	
4/4/2017	38XX N KENNETH AVE	1.9	2.7	1.9	0.9	
4/25/2017	38XX N KENNETH AVE	2.3	3.0	3.3	1.1	
5/4/2017	38XX N WHIPPLE ST <b>SITE 1</b>	0.8	1.2	1.4	0.5	
9/20/2017	38XX N WHIPPLE ST <b>SITE 1</b>	1.5	2.6	3.1	1.0	
5/9/2017	38XX N WHIPPLE ST <b>SITE 2</b>	13	26	23	5.6	
9/28/2017	38XX N WHIPPLE ST <b>SITE 2</b>	13	29	27	8.5	
8/10/2017	38XX N WHIPPLE ST <b>SITE 2</b>	See Follow-Up Sequential Sampling Table for Results				
5/27/2017	38XX N WHIPPLE ST <b>SITE 2</b>	See Follow-Up Sequential Sampling Table for Results				
9/20/2017	38XX N WHIPPLE ST <b>SITE 3</b>	4.5	0.7	0.5	0.3	
10/5/2017	38XX N WHIPPLE ST <b>SITE 3</b>	4.2	1.1	0.9	0.3	
5/9/2017	38XX N WHIPPLE ST <b>SITE 3</b>	4.5	0.9	0.7	0.4	
2/20/2018	38XX N WHIPPLE ST <b>SITE 3</b>	5.4	1.3	0.9	0.5	
1/17/2018	38XX N WHIPPLE ST <b>SITE 3</b>	5.7	3.2	1.0	0.5	0.5
12/13/2017	38XX N WHIPPLE ST <b>SITE 3</b>	16	1.5	1.1	0.6	
11/2/2017	38XX N WHIPPLE ST <b>SITE 3</b>	10	1.4	1.0	<0.3	
	38XX N WHIPPLE ST <b>SITE 3</b>	Customer declined further testing				
9/22/2017	39XX N WHIPPLE ST <b>SITE 1</b>	9.6	9.0	4.4	3.1	
5/5/2017	39XX N WHIPPLE ST <b>SITE 1</b>	5.1	12	6.6	7.9	
9/26/2017	39XX N WHIPPLE ST <b>SITE 2</b>	8.9	12	19	4.9	
5/4/2017	39XX N WHIPPLE ST <b>SITE 2</b>	12	33	25	5.1	
6/7/2017	39XX N WHIPPLE ST <b>SITE 2</b>	See Follow-Up Sequential Sampling Table for Results				
2/8/2018	39XX N WHIPPLE ST <b>SITE 3</b>	3.8	9.2	11	1.2	
1/11/2018	39XX N WHIPPLE ST <b>SITE 3</b>	5.0	11	12	1.3	
5/5/2017	39XX N WHIPPLE ST <b>SITE 3</b>	4.2	7.1	6.5	1.9	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
12/7/2017	39XX N WHIPPLE ST <b>SITE 3</b>	5.0	14	16	1.9		
11/2/2017	39XX N WHIPPLE ST <b>SITE 3</b>	5.3	14	15	2.5		
10/5/2017	39XX N WHIPPLE ST <b>SITE 3</b>	5.7	15	18	3.2		
9/19/2017	39XX N WHIPPLE ST <b>SITE 3</b>	7.4	15	15	9.1		
10/18/2017	39XX N WHIPPLE ST <b>SITE 3</b>	See Follow-Up Sequential Sampling Table for Results					
1/31/2018	39XX W 106TH ST	1.8	1.6	1.6	0.7		
3/17/2017	39XX W 57TH PL	1.8	3.0	2.9	1.3		
11/2/2016	39XX W 57TH PL	1.6	3.3	3.3	1.6		
2/7/2018	40XX W 83RD ST	1.4	1.5	1.6	0.5		
2/28/2018	40XX W 83RD ST	1.6	1.3	6.6	0.7		
1/12/2018	40XX W CARROLL AVE <b>SITE 1</b>	8.4	7.9	7.7	3.1		
11/17/2017	40XX W CARROLL AVE <b>SITE 1</b>	8.5	11	9.7	4.4		
7/6/2017	40XX W CARROLL AVE <b>SITE 1</b>	6.7	9.0	8.8	4.7		
12/15/2017	40XX W CARROLL AVE <b>SITE 1</b>	6.5	9.5	7.0	5.0		
9/29/2017	40XX W CARROLL AVE <b>SITE 1</b>	9.2	11	6.8	5.5	5.6	
2/23/2018	40XX W CARROLL AVE <b>SITE 1</b>	6.4	7.9	7.9	6.2		
10/20/2017	40XX W CARROLL AVE <b>SITE 1</b>	7.1	9.3	8.5	8.0	10	
2/23/2018	40XX W CARROLL AVE <b>SITE 2</b>	1.6	2.2	1.8	1.1		
1/12/2018	40XX W CARROLL AVE <b>SITE 2</b>	1.7	2.3	2.1	1.1		
11/28/2017	40XX W CARROLL AVE <b>SITE 2</b>	1.4	2.3	2.8	1.1		
7/7/2017	40XX W CARROLL AVE <b>SITE 2</b>	1.5	2.4	1.9	1.2		
12/15/2017	40XX W CARROLL AVE <b>SITE 2</b>	1.5	2.6	3.1	1.2		
10/20/2017	40XX W CARROLL AVE <b>SITE 2</b>	1.4	2.3	3.5	1.6		
9/29/2017	40XX W CARROLL AVE <b>SITE 2</b>	2.0	2.7	4.3	1.9		
10/30/2017	41XX N DRAKE AVE	0.6	0.5	0.4	0.5		
10/6/2017	41XX N DRAKE AVE	0.4	0.7	1.0	0.6		
10/19/2017	41XX N HAMLIN AVE	6.7	2.4	1.5	2.1		
10/30/2017	41XX N LEAMINGTON AVE	1.2	2.0	1.9	1.0		
11/13/2017	41XX N LEAMINGTON AVE	1.3	2.7	3.7	1.2		
6/2/2017	41XX N TROY ST	1.2	2.5	2.5	1.7		
6/13/2017	41XX N TROY ST	2.0	5.3	3.6	2.0		
2/28/2018	41XX S MICHIGAN AVE	6.8	8.1	18	3.0		
1/25/2018	41XX S MICHIGAN AVE	6.3	7.1	17	3.1		
12/7/2017	41XX S MICHIGAN AVE	9.0	9.1	20	4.1		
10/25/2017	41XX S MICHIGAN AVE	8.9	9.9	19	5.4		
6/21/2017	41XX S MICHIGAN AVE	9.6	7.2	6.3	5.7		

all results are shown in PPB (Parts per Billion)



Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
11/22/2017	41XX S MICHIGAN AVE	See Follow-Up Sequential Sampling Table for Results				
10/20/2017	42XX N HAMLIN AVE <b>SITE 1</b>	3.7	6.3	5.3	3.4	
10/20/2017	42XX N HAMLIN AVE <b>SITE 2</b>	2.4	2.3	1.8	1.5	
10/20/2017	42XX N HAMLIN AVE <b>SITE 3</b>	1.3	0.3	<0.3	<0.3	
10/19/2017	42XX N HAMLIN AVE <b>SITE 4</b>	5.8	21	17	8.1	
11/8/2017	42XX N HAMLIN AVE <b>SITE 4</b>	See Follow-Up Sequential Sampling Table for Results				
10/20/2017	42XX N LAWDALE AVE	2.7	4.5	10	1.9	
10/24/2017	42XX S INDIANA AVE	0.9	1.0	1.4	1.2	1.1
6/21/2017	42XX S INDIANA AVE	0.9	1.3	1.7	1.5	
2/22/2017	42XX W HIRSCH ST	1.1	0.6	0.7	0.5	
3/1/2017	42XX W HIRSCH ST	1.9	0.7	0.7	0.6	
4/26/2017	43XX N CAMPBELL AVE	2.4	5.1	5.7	2.0	
5/10/2017	43XX N CAMPBELL AVE	6.3	5.6	5.9	2.0	
10/19/2017	43XX N HAMLIN AVE <b>SITE 1</b>	2.5	4.8	3.5	2.2	
10/19/2017	43XX N HAMLIN AVE <b>SITE 2</b>	1.5	2.2	2.1	1.3	
10/23/2017	43XX N HAMLIN AVE <b>SITE 3</b>	6.0	7.1	8.1	3.6	
10/19/2017	43XX N HAMLIN AVE <b>SITE 4</b>	0.5	<0.3	<0.3	<0.3	
12/15/2017	43XX N MASON AVE	0.9	1.3	2.1	0.6	
11/17/2017	43XX N MASON AVE	1.1	1.4	1.6	0.9	
11/3/2017	43XX W IRVING PARK RD	1.0	0.8	0.7	0.6	
11/16/2017	43XX W IRVING PARK RD	1.0	0.8	0.8	0.6	
1/4/2018	43XX W POTOMAC AVE	2.6	0.4	0.4	0.3	0.4
2/26/2018	43XX W POTOMAC AVE	2.0	0.4	<0.3	<0.3	
2/22/2018	43XX W SCHOOL ST	4.7	7.6	8.8	2.8	
1/18/2018	43XX W SCHOOL ST	5.2	8.7	15	2.9	
12/14/2017	43XX W SCHOOL ST	5.4	8.1	18	3.5	
10/27/2017	43XX W SCHOOL ST	4.0	5.2	5.4	3.6	
1/6/2018	43XX W SCHOOL ST	See Follow-Up Sequential Sampling Table for Results				
1/4/2017	44XX N ALBANY AVE <b>SITE 1</b>	6.2	2.7	2.9	1.1	
9/20/2016	44XX N ALBANY AVE <b>SITE 1</b>	1.9	2.0	2.1	1.2	
9/20/2016	44XX N ALBANY AVE <b>SITE 1</b>	8.7	13	13	2.7	
9/30/2016	44XX N ALBANY AVE <b>SITE 2</b>	0.5	0.6	0.6	0.4	
1/4/2017	44XX N ALBANY AVE <b>SITE 2</b>	1.2	1.1	1.5	0.5	0.5
10/27/2016	44XX N HAMILTON AVE	1.7	1.9	1.8	1.1	
1/18/2017	44XX N HAMILTON AVE	1.0	2.2	3.2	1.2	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
11/13/2017	44XX N MULLIGAN AVE	6.4	7.7	7.6	5.1	
10/24/2017	44XX N MULLIGAN AVE	3.6	7.0	9.6	14	
2/12/2018	44XX N SACRAMENTO AVE <b>SITE 1</b>	3.2	3.1	3.0	1.4	
7/25/2017	44XX N SACRAMENTO AVE <b>SITE 1</b>	4.2	3.9	3.6	3.5	
2/12/2018	44XX N SACRAMENTO AVE <b>SITE 2</b>	6.8	6.3	6.7	3.1	
8/9/2017	44XX N SACRAMENTO AVE <b>SITE 2</b>	8.6	7.5	9.2	6.1	
2/13/2018	44XX N SACRAMENTO AVE <b>SITE 3</b>	11	6.1	5.9	2.0	
8/9/2017	44XX N SACRAMENTO AVE <b>SITE 3</b>	4.5	6.7	6.3	4.3	
2/12/2018	44XX N SACRAMENTO AVE <b>SITE 4</b>	1.5	2.0	2.1	1.2	
8/9/2017	44XX N SACRAMENTO AVE <b>SITE 4</b>	1.4	2.0	2.0	2.3	
2/22/2018	44XX N WHIPPLE ST <b>SITE 1</b>	1.7	1.4	1.3	1.0	
7/25/2017	44XX N WHIPPLE ST <b>SITE 1</b>	6.9	10	8.6	3.0	
2/12/2018	44XX N WHIPPLE ST <b>SITE 2</b>	3.4	1.9	1.9	3.1	
7/25/2017	44XX N WHIPPLE ST <b>SITE 2</b>	12	7.9	4.0	6.0	
10/24/2017	44XX S INDIANA AVE <b>SITE 1</b>	2.5	3.8	3.6	3.1	
6/21/2017	44XX S INDIANA AVE <b>SITE 1</b>	4.1	5.0	5.5	3.5	
10/24/2017	44XX S INDIANA AVE <b>SITE 2</b>	1.9	2.9	3.0	2.0	
6/29/2017	44XX S INDIANA AVE <b>SITE 2</b>	1.7	2.2	2.4	2.3	
11/2/2016	44XX W GRENSHAW ST	8.7	7.1	2.4	1.4	
9/7/2016	44XX W GRENSHAW ST	8.2	6.5	3.5	2.3	2.3
1/4/2017	45XX N ALBANY AVE <b>SITE 1</b>	2.3	3.1	3.2	1.9	
9/20/2016	45XX N ALBANY AVE <b>SITE 1</b>	4.1	11	12	2.5	
1/11/2017	45XX N ALBANY AVE <b>SITE 2</b>	1.6	3.4	3.1	2.8	
9/21/2016	45XX N ALBANY AVE <b>SITE 2</b>	1.7	2.5	2.7	6.7	4.1
3/1/2017	45XX N ALBANY AVE <b>SITE 3</b>	13	23	14	3.1	
4/19/2017	45XX N ALBANY AVE <b>SITE 3</b>	34	43	29	4.4	
6/14/2017	45XX N ALBANY AVE <b>SITE 3</b>	14	25	18	5.0	
9/20/2016	45XX N ALBANY AVE <b>SITE 3</b>	12	20	18	5.1	
5/17/2017	45XX N ALBANY AVE <b>SITE 3</b>	15	35	20	5.3	
7/12/2017	45XX N ALBANY AVE <b>SITE 3</b>	16	28	20	5.9	12.0
8/18/2017	45XX N ALBANY AVE <b>SITE 3</b>	35	30	25	7.3	
10/29/2016	45XX N ALBANY AVE <b>SITE 3</b>	See Follow-Up Sequential Sampling Table for Results				
7/26/2017	45XX N SACRAMENTO AVE <b>SITE 1</b>	2.5	7.1	7.4	2.3	2.2
7/26/2017	45XX N SACRAMENTO AVE <b>SITE 2</b>	2.6	3.5	3.8	3.6	
2/12/2018	45XX N SACRAMENTO AVE <b>SITE 2</b>	4.1	2.7	2.9	3.7	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
7/25/2017	45XX N SACRAMENTO AVE <b>SITE 3</b>	0.8	0.8	0.8	0.7	
2/12/2018	45XX N SACRAMENTO AVE <b>SITE 3</b>	0.8	1.3	1.4	0.7	
8/4/2017	45XX N SACRAMENTO AVE <b>SITE 4</b>	1.7	3.6	6.4	1.8	
2/12/2018	45XX N SACRAMENTO AVE <b>SITE 5</b>	2.4	5.5	5.3	2.4	
8/17/2017	45XX N SACRAMENTO AVE <b>SITE 5</b>	8.3	7.4	7.0	3.0	
2/12/2018	45XX N SACRAMENTO AVE <b>SITE 6</b>	2.8	5.8	5.8	2.6	
8/22/2017	45XX N SACRAMENTO AVE <b>SITE 6</b>	2.9	4.0	3.6	2.7	
10/20/2017	45XX N SPAULDING AVE	3.1	4.2	10	2.2	
12/20/2017	45XX N SPAULDING AVE	3.7	5.7	9.5	2.4	
2/12/2018	45XX N WHIPPLE ST <b>SITE 1</b>	2.0	2.2	2.0	0.5	
7/25/2017	45XX N WHIPPLE ST <b>SITE 1</b>	2.9	2.3	1.9	1.2	
2/12/2018	45XX N WHIPPLE ST <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
7/26/2017	45XX N WHIPPLE ST <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
2/13/2018	45XX N WHIPPLE ST <b>SITE 3</b>	0.8	1.8	0.7	0.3	
8/9/2017	45XX N WHIPPLE ST <b>SITE 3</b>	1.0	1.1	1.0	0.5	
8/17/2017	45XX N WHIPPLE ST <b>SITE 3</b>	2.4	3.3	5.1	2.3	2.3
2/12/2018	45XX N WHIPPLE ST <b>SITE 4</b>	8.6	5.1	4.4	3.2	
8/4/2017	45XX N WHIPPLE ST <b>SITE 4</b>	5.9	26	19	6.1	
9/16/2017	45XX N WHIPPLE ST <b>SITE 4</b>	See Follow-Up Sequential Sampling Table for Results				
12/28/2017	46XX N LECLAIRE AVE	3.0	4.9	5.7	0.6	
12/1/2017	46XX N LECLAIRE AVE	2.0	2.2	2.9	1.0	
2/16/2018	47XX N MANOR AVE	4.6	5.4	5.7	1.4	
2/22/2018	47XX N SACRAMENTO AVE <b>SITE 1</b>	5.9	5.8	5.5	1.5	
7/25/2017	47XX N SACRAMENTO AVE <b>SITE 1</b>	5.6	8.2	8.0	3.5	
2/12/2018	47XX N SACRAMENTO AVE <b>SITE 2</b>	0.6	0.5	0.5	0.4	
7/28/2017	47XX N SACRAMENTO AVE <b>SITE 2</b>	1.7	2.1	2.0	1.4	
8/29/2017	48XX N MARRIMAC AVE	2.6	1.7	2.8	1.8	
9/6/2017	48XX N MARRIMAC AVE	2.6	1.7	2.9	2.2	
4/5/2017	48XX W EDDY ST	1.2	1.3	1.3	0.5	
4/18/2017	48XX W EDDY ST	2.0	0.8	1.0	0.7	
10/20/2017	49XX N GLENWOOD AVE	4.5	5.4	6.2	1.6	
10/20/2017	49XX N MAGNOLIA AVE <b>SITE 1</b>	2.5	2.6	5.8	1.6	
10/18/2017	49XX N MAGNOLIA AVE <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
1/4/2018	49XX N MERRIMA	1.0	0.9	0.9	0.6	
5/1/2017	49XX W CORTEZ ST	9.0	3.0	2.7	2.4	2.4

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
5/3/2017	49XX W SUPERIOR ST	2.7	2.5	2.8	1.5	
4/24/2017	49XX W WALTON ST	0.4	0.5	0.6	0.3	0.3
9/29/2017	49XX W WALTON ST	0.4	0.5	0.4	0.4	
1/10/2017	4XX W 101ST PL <b>SITE 1</b>	1.4	0.8	0.6	0.5	
9/28/2016	4XX W 101ST PL <b>SITE 1</b>	1.8	1.5	1.9	1.1	
9/29/2016	4XX W 101ST PL <b>SITE 2</b>	3.5	5.8	7.2	3.1	
1/10/2017	4XX W 101ST PL <b>SITE 2</b>	5.3	6.9	6.2	6.8	
1/11/2017	4XX W 101ST PL <b>SITE 3</b>	2.6	2.3	4.2	1.6	
9/29/2016	4XX W 101ST PL <b>SITE 3</b>	1.6	2.4	2.4	1.7	
1/10/2017	4XX W 101ST PL <b>SITE 4</b>	1.0	1.9	5.3	0.6	
9/28/2016	4XX W 101ST PL <b>SITE 4</b>	0.9	2.1	2.2	1.0	
1/11/2017	4XX W 101ST PL <b>SITE 5</b>	6.2	8.4	7.6	2.8	
9/29/2016	4XX W 101ST PL <b>SITE 5</b>	4.9	7.9	9.4	6.0	
1/10/2017	4XX W 101ST PL <b>SITE 6</b>	0.9	1.7	6.4	0.5	
4/4/2017	4XX W 101ST PL <b>SITE 6</b>	1.0	1.9	1.8	0.6	
2/8/2017	4XX W 101ST PL <b>SITE 6</b>	1.0	2.3	1.8	0.6	
3/10/2017	4XX W 101ST PL <b>SITE 6</b>	0.8	2.4	1.8	0.6	
9/29/2016	4XX W 101ST PL <b>SITE 6</b>	1.3	2.5	2.3	1.1	
5/9/2017	4XX W 101ST PL <b>SITE 6</b>	1.0	3.6	2.5	1.1	
6/6/2017	4XX W 101ST PL <b>SITE 6</b>	1.2	3.6	2.5	1.1	
9/28/2016	4XX W 101ST PL <b>SITE 7</b>	4.8	2.6	2.8	2.8	
1/19/2017	4XX W 102ND ST	2.6	3.0	3.1	0.9	0.9
9/28/2016	4XX W 102ND ST	3.3	4.2	3.6	2.9	
1/10/2017	4XX W 103RD ST <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
9/29/2016	4XX W 103RD ST <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	
11/1/2017	4XX W 103RD ST <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	<0.3
2/6/2018	50XX N MELVINA AVE	8.2	2.2	2.6	0.6	0.6
1/24/2018	50XX N MELVINA AVE	1.6	2.0	3.2	0.7	
4/25/2017	50XX N NEENAH AVE	2.8	3.7	5.1	0.8	
5/10/2017	50XX N NEENAH AVE	3.8	5.0	6.3	1.1	
12/4/2017	50XX N WINCHESTER AVE	5.9	7.6	5.7	3.8	
9/20/2017	50XX N WINCHESTER AVE	8.7	22	20	8.6	
10/26/2017	50XX N WINCHESTER AVE	See Follow-Up Sequential Sampling Table for Results				
10/13/2017	50XX W BALMORAL AVE	3.7	7.1	7.0	3.3	
9/20/2017	50XX W BALMORAL AVE	4.2	8.6	9.0	3.4	3.5

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
2/21/2018	51XX N MERRIMAC AVE	1.1	0.8	1.0	0.5		
1/26/2018	51XX N MERRIMAC AVE	1.2	0.9	0.9	0.6		
11/30/2017	51XX N WINCHESTER AVE	3.7	4.4	4.4	2.2		
9/20/2017	51XX N WINCHESTER AVE	4.0	6.0	11	4.3		
10/12/2017	51XX S LONG AVE	3.1	5.9	4.4	2.6	2.5	
9/22/2017	51XX S LONG AVE	2.9	5.0	4.2	2.7		
10/3/2017	51XX S MORGAN ST	1.2	2.7	3.2	1.4		
10/3/2017	52XX S MORGAN ST <b>SITE 1</b>	6.0	9.1	8.1	5.7		
10/3/2017	52XX S MORGAN ST <b>SITE 2</b>	0.6	1.0	0.9	0.9		
8/30/2016	52XX W CONGRESS PKWY <b>SITE 1</b>	2.9	3.1	3.7	5.5		
8/29/2016	52XX W CONGRESS PKWY <b>SITE 2</b>	2.5	1.7	1.7	1.8		
8/30/2016	52XX W CONGRESS PKWY <b>SITE 3</b>	2.7	1.2	1.1	0.8	0.8	
12/1/2016	52XX W CONGRESS PKWY <b>SITE 4</b>	6.1	7.4	6.4	3.7		
8/31/2016	52XX W CONGRESS PKWY <b>SITE 4</b>	5.5	5.3	5.1	3.9		
3/16/2017	53XX N BERNARD ST**	3.8	3.3	3.0	2.6	2.6	
4/7/2017	53XX N BERNARD ST**	7.3	20	*	16		
7/15/2017	53XX N BERNARD ST**	See Follow-Up Sequential Sampling Table for Results					
4/29/2017	53XX N BERNARD ST**	See Follow-Up Sequential Sampling Table for Results					
11/9/2017	53XX N LATROBE AVE	1.0	0.6	0.7	0.4		
12/7/2017	53XX N LATROBE AVE	1.0	0.8	1.0	0.5		
2/16/2018	53XX N LIEB AVE	8.4	6.5	6.7	2.2		
1/19/2018	53XX N LIEB AVE	10	7.5	7.7	3.0		
12/8/2017	53XX N LIEB AVE	9.9	8.7	9.9	3.5		
10/13/2017	53XX N LIEB AVE	13	13	14	5.5		
9/20/2017	53XX N LIEB AVE	8.0	14	14	6.7		
10/13/2017	53XX S MORGAN ST	1.4	0.4	0.4	0.4		
11/1/2017	53XX S SPAULDING AVE	3.4	6.9	7.3	2.1		
12/1/2016	53XX W CONGRESS PKWY <b>SITE 1</b>	7.9	4.0	5.0	3.2		
8/29/2016	53XX W CONGRESS PKWY <b>SITE 1</b>	4.3	6.4	6.0	3.9		
8/30/2016	53XX W CONGRESS PKWY <b>SITE 2</b>	2.1	2.2	2.6	1.9		
12/1/2016	53XX W CONGRESS PKWY <b>SITE 2</b>	2.5	2.6	2.6	1.9		
8/30/2016	53XX W CONGRESS PKWY <b>SITE 3</b>	2.4	1.2	1.2	1.0		
12/2/2016	53XX W CONGRESS PKWY <b>SITE 3</b>	4.1	3.4	3.4	2.1	1.3	
12/14/2016	53XX W CONGRESS PKWY <b>SITE 4</b>	3.0	4.2	3.0	1.8		
8/31/2016	53XX W CONGRESS PKWY <b>SITE 4</b>	3.8	9.9	8.0	3.4		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
10/23/2017	54XX N LOTUS AVE	5.3	3.9	4.0	2.7	
10/10/2017	54XX N LOTUS AVE	13	8.9	8.1	4.0	
2/1/2018	54XX N MOBILE AVE	2.9	1.3	1.2	0.3	
6/8/2017	54XX S HOYNE AVE	3.6	5.5	6.6	2.0	
11/8/2017	54XX S MORGAN ST <b>SITE 1</b>	<0.3	<0.3	<0.3	<0.3	<0.3
11/8/2017	54XX S MORGAN ST <b>SITE 2</b>	<0.3	<0.3	<0.3	<0.3	
6/7/2017	54XX S SEELEY AVE <b>SITE 1</b>	1.8	1.6	1.6	0.9	
6/16/2017	54XX S SEELEY AVE <b>SITE 2</b>	<0.3	0.3	<0.3	<0.3	
11/1/2017	54XX S SPAULDING AVE	3.1	1.8	1.9	1.5	
2/1/2017	54XX W CONGRESS PKWY <b>SITE 1</b>	0.9	0.9	0.4	0.3	0.4
8/29/2016	54XX W CONGRESS PKWY <b>SITE 1</b>	0.5	0.5	0.5	0.3	
3/1/2017	54XX W CONGRESS PKWY <b>SITE 1</b>	0.9	0.7	0.4	0.4	
4/5/2017	54XX W CONGRESS PKWY <b>SITE 1</b>	0.8	0.7	0.5	0.4	0.4
5/3/2017	54XX W CONGRESS PKWY <b>SITE 1</b>	0.8	0.8	0.5	0.4	
12/1/2016	54XX W CONGRESS PKWY <b>SITE 1</b>	1.2	0.8	0.6	0.4	
6/7/2017	54XX W CONGRESS PKWY <b>SITE 1</b>	0.8	0.8	0.6	0.5	
8/31/2016	54XX W CONGRESS PKWY <b>SITE 2</b>	1.9	0.4	0.4	0.4	
8/30/2016	54XX W CONGRESS PKWY <b>SITE 3</b>	0.7	2.2	2.6	0.6	
12/6/2016	54XX W CONGRESS PKWY <b>SITE 3</b>	1.0	1.2	1.2	0.7	
8/30/2016	54XX W CONGRESS PKWY <b>SITE 4</b>	3.6	4.3	3.9	2.1	
12/2/2016	54XX W CONGRESS PKWY <b>SITE 4</b>	4.4	4.7	6.0	2.1	
8/31/2016	54XX W CONGRESS PKWY <b>SITE 5</b>	3.1	4.6	4.3	2.3	
12/2/2016	54XX W CONGRESS PKWY <b>SITE 5</b>	2.9	3.9	3.6	2.7	
1/26/2018	54XX W DRUMMOND PL	1.8	0.7	1.6	1.5	
8/1/2017	56XX S CHRISTIANA AVE <b>SITE 1</b>	5.0	3.9	4.1	3.5	
2/1/2018	56XX S CHRISTIANA AVE <b>SITE 2</b>	1.8	1.8	1.9	1.9	
8/2/2017	56XX S CHRISTIANA AVE <b>SITE 2</b>	3.1	4.0	7.9	5.2	
8/2/2017	56XX S CHRISTIANA AVE <b>SITE 3</b>	5.3	1.5	1.5	2.7	
8/1/2017	56XX S CHRISTIANA AVE <b>SITE 4</b>	1.0	1.3	1.0	0.8	
2/1/2018	56XX S CHRISTIANA AVE <b>SITE 4</b>	2.5	0.6	0.8	1.4	
1/26/2018	56XX S MERRIMAC AVE	1.1	0.7	0.7	0.9	
1/24/2018	56XX W WAVELAND AVE	7.5	2.2	1.4	0.7	
8/31/2017	57XX N MELVINA AVE	1.8	1.6	1.8	1.1	1.1
8/1/2017	57XX S CHRISTIANA AVE <b>SITE 1</b>	0.8	0.5	0.6	0.7	
2/1/2018	57XX S CHRISTIANA AVE <b>SITE 2</b>	1.9	1.8	1.9	1.1	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
8/1/2017	57XX S CHRISTIANA AVE <b>SITE 2</b>	4.8	5.0	7.0	2.6	2.5
9/18/2017	57XX S CHRISTIANA AVE <b>SITE 3</b>	1.3	1.4	1.8	0.9	0.9
2/2/2018	57XX S CHRISTIANA AVE <b>SITE 3</b>	1.8	1.4	1.4	1.0	
8/25/2017	57XX S OAK PARK AVE	2.3	1.7	1.8	1.6	
9/22/2017	57XX S OAK PARK AVE	1.6	1.8	1.8	2.2	
2/13/2018	57XX W MIDWAY PARK <b>SITE 1</b>	1.1	1.5	1.7	2.2	
4/19/2017	57XX W MIDWAY PARK <b>SITE 1</b>	1.5	1.9	3.6	2.4	
12/14/2017	57XX W MIDWAY PARK <b>SITE 1</b>	1.3	1.7	2.4	2.9	2.2
1/11/2018	57XX W MIDWAY PARK <b>SITE 1</b>	1.3	3.0	2.7	3.0	
4/19/2017	57XX W MIDWAY PARK <b>SITE 2</b>	1.8	2.5	2.5	1.0	
12/13/2017	57XX W MIDWAY PARK <b>SITE 2</b>	2.5	2.2	2.5	1.1	
12/13/2017	57XX W RACE AVE	5.1	6.0	7.2	4.1	4.2
4/26/2017	57XX W RACE AVE	6.6	15	17	6.9	
5/17/2017	57XX W RACE AVE	See Follow-Up Sequential Sampling Table for Results				
2/2/2018	58XX S CHRISTIANA AVE	3.2	2.2	2.4	1.6	
8/1/2017	58XX S CHRISTIANA AVE	3.8	3.3	7.8	3.0	
2/23/2018	58XX S MELVINA AVE	3.3	2.2	2.4	1.3	
1/26/2018	58XX S MELVINA AVE	6.0	4.7	3.9	1.3	
2/8/2018	58XX S RUTHERFORD AVE	2.1	4.2	7.9	1.2	
1/23/2018	58XX S RUTHERFORD AVE	3.0	6.8	12	1.3	
12/14/2017	58XX S RUTHERFORD AVE	2.4	8.1	12	1.5	
11/2/2017	58XX S RUTHERFORD AVE	2.7	8.7	14	2.1	
10/5/2017	58XX S RUTHERFORD AVE	2.7	6.4	8.5	2.2	2.0
8/22/2017	58XX S RUTHERFORD AVE	2.8	12	12	2.2	
9/7/2017	58XX S RUTHERFORD AVE	8.6	11	10	2.3	
2/26/2018	58XX W BYRON ST	0.7	1.0	1.2	0.6	
10/23/2017	58XX W BYRON ST	0.6	1.3	1.9	0.9	
2/20/2018	58XX W FOSTER AVE	0.9	1.7	1.6	<0.3	
6/5/2017	59XX S CAMPBELL AVE	0.8	0.6	1.0	0.6	
2/16/2018	59XX W AUGUSTA BLVD	2.1	0.9	0.7	0.6	
2/16/2018	60XX N KILPATRICK AVE	2.1	3.2	3.3	1.1	
1/26/2018	60XX N KILPATRICK AVE	1.3	1.5	1.7	1.2	
4/13/2017	60XX N LEADER AVE	5.3	8.2	12	2.2	
6/2/2017	60XX N LEADER AVE	7.2	7.5	8.0	2.5	
1/3/2018	60XX S CAMPBELL AVE <b>SITE 1</b>	2.4	1.4	1.6	0.8	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
6/5/2017	60XX S CAMPBELL AVE <b>SITE 1</b>	1.4	2.0	2.7	1.6	
2/27/2018	60XX S CAMPBELL AVE <b>SITE 2</b>	2.3	2.5	2.7	1.0	
1/5/2018	60XX S CAMPBELL AVE <b>SITE 2</b>	3.6	2.8	2.6	1.1	
6/5/2017	60XX S CAMPBELL AVE <b>SITE 2</b>	2.3	3.1	3.2	1.8	1.9
1/3/2018	60XX S CAMPBELL AVE <b>SITE 3</b>	0.6	0.9	1.2	0.5	
6/5/2017	60XX S CAMPBELL AVE <b>SITE 3</b>	0.5	0.6	0.4	<0.3	
6/6/2017	60XX S CAMPBELL AVE <b>SITE 4</b>	1.8	1.4	1.6	0.7	
1/3/2018	60XX S CAMPBELL AVE <b>SITE 4</b>	2.6	5.0	9.0	1.1	
6/12/2017	60XX S CAMPBELL AVE <b>SITE 5</b>	1.0	0.9	0.7	0.5	
6/5/2017	60XX S CAMPBELL AVE <b>SITE 6</b>	3.1	3.9	3.3	2.1	
2/13/2017	60XX S KOLIN AVE	0.7	0.6	0.5	0.4	
3/8/2017	60XX S KOLIN AVE	0.5	<0.3	<0.3	<0.3	
2/9/2017	60XX S MOODY AVE	1.2	1.0	1.2	0.3	
1/17/2017	60XX S MOODY AVE	0.8	0.6	0.7	<0.3	<0.3
1/4/2018	61XX S CALIFORNIA AVE	1.7	3.5	2.4	0.8	
2/2/2018	61XX S CALIFORNIA AVE	2.0	1.7	1.4	0.9	
2/27/2018	61XX S CAMPBELL AVE	1.1	1.1	1.4	0.5	0.5
6/12/2017	61XX S CAMPBELL AVE	2.3	1.4	1.9	1.0	
1/5/2018	61XX S CAMPBELL AVE	2.0	1.9	3.1	1.4	
2/2/2017	61XX S MOODY AVE	1.2	2.5	2.7	1.5	
2/23/2017	61XX S MOODY AVE	1.7	4.4	11	1.5	
10/25/2017	61XX W LELAND AVE	0.8	0.3	0.3	0.4	
11/16/2017	61XX W LELAND AVE	1.4	1.2	1.5	0.7	
5/4/2017	62XX N KIRKWOOD AVE	3.0	4.8	4.9	2.6	
5/31/2017	62XX N KIRKWOOD AVE	4.0	5.6	4.8	3.2	
1/3/2018	62XX S CAMPBELL AVE	0.5	<0.3	<0.3	<0.3	
6/5/2017	62XX S CAMPBELL AVE	0.6	<0.3	<0.3	<0.3	
9/25/2017	62XX W GRAND AVE	4.0	1.4	2.8	0.6	0.6
10/9/2017	62XX W GRAND AVE	4.0	1.4	8.3	0.6	
4/4/2017	63XX S KILPATRICK AVE <b>SITE 1</b>	1.3	1.5	1.5	0.8	
12/5/2017	63XX S KILPATRICK AVE <b>SITE 1</b>	1.3	1.9	2.1	0.9	
10/30/2017	63XX S KILPATRICK AVE <b>SITE 1</b>	1.2	1.7	2.2	1.0	
9/27/2017	63XX S KILPATRICK AVE <b>SITE 1</b>	1.2	1.7	2.3	1.3	
6/28/2017	63XX S KILPATRICK AVE <b>SITE 1</b>	3.7	2.0	1.8	1.5	
8/3/2017	63XX S KILPATRICK AVE <b>SITE 1</b>	1.1	1.7	1.4	1.6	

all results are shown in PPB (Parts per Billion)



Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
8/17/2017	63XX S KILPATRICK AVE <b>SITE 1</b>	1.3	2.1	2.1	1.6	
4/5/2017	63XX S KILPATRICK AVE <b>SITE 2</b>	1.8	2.5	3.0	1.4	
11/16/2017	63XX S KILPATRICK AVE <b>SITE 2</b>	2.3	4.0	5.3	1.6	1.6
10/24/2017	63XX S KILPATRICK AVE <b>SITE 2</b>	2.0	3.9	5.1	2.0	
6/27/2017	63XX S KILPATRICK AVE <b>SITE 2</b>	2.6	3.9	3.4	2.7	
9/28/2017	63XX S KILPATRICK AVE <b>SITE 2</b>	3.5	4.1	4.6	2.7	
8/25/2017	63XX S KILPATRICK AVE <b>SITE 2</b>	2.2	4.0	4.6	2.8	
7/20/2017	63XX S KILPATRICK AVE <b>SITE 2</b>	2.6	4.5	5.2	2.8	
4/11/2017	64XX S KILPATRICK AVE	4.5	13	13	2.6	
6/29/2017	64XX S KILPATRICK AVE	7.5	14	13	3.8	
5/31/2017	64XX S MAPLEWOOD AVE	1.5	1.4	1.5	0.9	
6/8/2017	64XX S MAPLEWOOD AVE	1.8	1.4	1.4	1.0	
4/11/2017	65XX S KILPATRICK AVE <b>SITE 1</b>	2.7	3.3	2.3	1.5	
6/22/2017	65XX S KILPATRICK AVE <b>SITE 1</b>	3.4	8.0	13	3.4	
4/5/2017	65XX S KILPATRICK AVE <b>SITE 2</b>	1.4	1.8	1.8	0.9	0.9
6/28/2017	65XX S KILPATRICK AVE <b>SITE 2</b>	2.3	2.6	2.8	1.5	
4/6/2017	65XX S KILPATRICK AVE <b>SITE 3</b>	4.1	5.4	4.1	1.0	
6/27/2017	65XX S KILPATRICK AVE <b>SITE 3</b>	3.6	7.2	4.6	1.9	
4/5/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	0.7	1.4	1.0	0.6	
11/15/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	0.7	1.2	1.4	1.9	
7/28/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	1.2	1.8	2.2	2.5	
8/18/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	0.9	1.6	2.4	2.5	
9/26/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	0.8	1.1	1.5	2.7	
6/28/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	13	1.8	2.6	3.0	
10/17/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	2.1	1.3	5.9	21	
12/9/2017	65XX S KILPATRICK AVE <b>SITE 4</b>	See Follow-Up Sequential Sampling Table for Results				
1/23/2018	65XX S MARYLAND AVE	1.1	1.6	1.8	0.6	
12/19/2017	65XX S MARYLAND AVE	1.2	1.4	1.4	0.7	
11/17/2017	65XX S MARYLAND AVE	1.1	1.4	1.9	0.8	
4/19/2017	65XX S MARYLAND AVE	1.1	2.3	1.8	0.9	
10/17/2017	65XX S MARYLAND AVE	1.0	1.7	1.6	1.1	
9/26/2017	65XX S MARYLAND AVE	1.1	2.1	1.8	1.5	1.4
8/22/2017	65XX S MARYLAND AVE	1.3	2.0	2.8	1.5	
4/17/2017	65XX S ROCKWELL ST	1.5	2.3	2.7	1.0	
11/3/2017	66XX N ODELL AVE	3.7	5.0	6.5	2.9	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
9/29/2017	66XX N ODELL AVE	4.0	6.3	5.3	3.4	
4/5/2017	66XX S KILPATRICK AVE <b>SITE 1</b>	2.6	3.8	7.5	1.8	
11/16/2017	66XX S KILPATRICK AVE <b>SITE 1</b>	2.9	4.2	13	2.1	
9/27/2017	66XX S KILPATRICK AVE <b>SITE 1</b>	2.7	2.1	2.7	2.3	
7/28/2017	66XX S KILPATRICK AVE <b>SITE 1</b>	2.6	3.0	4.6	2.5	
10/24/2017	66XX S KILPATRICK AVE <b>SITE 1</b>	2.7	3.4	5.5	2.5	
8/18/2017	66XX S KILPATRICK AVE <b>SITE 1</b>	3.0	5.4	8.2	3.7	
6/28/2017	66XX S KILPATRICK AVE <b>SITE 1</b>	4.0	5.6	8.1	3.8	
4/6/2017	66XX S KILPATRICK AVE <b>SITE 2</b>	1.5	1.3	0.9	0.5	
6/22/2017	66XX S KILPATRICK AVE <b>SITE 2</b>	1.9	1.1	1.0	0.9	
4/5/2017	66XX S KILPATRICK AVE <b>SITE 3</b>	1.8	1.7	1.9	1.6	
6/27/2017	66XX S KILPATRICK AVE <b>SITE 3</b>	2.8	4.9	5.4	3.2	
4/4/2017	66XX S KILPATRICK AVE <b>SITE 4</b>	8.0	9.4	10	2.5	
6/27/2017	66XX S KILPATRICK AVE <b>SITE 4</b>	10	11	12	8.3	
4/6/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	2.0	4.3	2.3	0.8	
11/16/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	2.4	3.9	4.0	1.2	
10/24/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	2.7	3.7	4.0	1.5	
9/27/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	2.1	2.8	3.0	1.8	
8/25/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	6.5	6.2	9.5	2.6	
7/20/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	4.8	8.3	47	3.8	
6/22/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	4.0	5.8	8.4	5.0	
9/29/2017	66XX S KILPATRICK AVE <b>SITE 5</b>	See Follow-Up Sequential Sampling Table for Results				
2/8/2017	67XX N JEAN AVE	2.9	7.7	9.1	1.7	
6/13/2017	67XX N JEAN AVE	2.6	12	15	2.6	
5/16/2017	67XX N JEAN AVE	6.0	19	23	2.9	
7/18/2017	67XX N JEAN AVE	3.5	10	17	3.3	
8/18/2017	67XX N JEAN AVE	5.4	16	23	3.7	
10/13/2017	67XX N JEAN AVE	4.4	11	21	3.9	
9/20/2017	67XX N JEAN AVE	4.6	11	28	4.5	
6/9/2017	67XX N JEAN AVE	See Follow-Up Sequential Sampling Table for Results				
1/18/2018	67XX N RICHMOND ST	0.8	1.0	1.0	0.4	
1/30/2018	67XX S CREGIER AVE	1.9	1.7	1.9	1.0	
2/28/2018	67XX S CREGIER AVE	13	3.5	3.7	1.3	
1/17/2017	67XX W 64TH ST	3.5	2.6	3.1	0.9	
2/13/2017	67XX W 64TH ST	8.0	3.3	3.0	1.1	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
7/28/2017	68XX S NORMAL BLVD	3.1	5.8	4.6	3.3	
1/26/2018	68XX W 64TH PL	3.3	4.2	4.3	0.8	
2/20/2018	68XX W 64TH PL	3.6	4.3	4.7	0.8	0.8
2/20/2018	69XX W ARMITAGE AVE	4.0	5.1	6.2	2.5	
11/3/2017	6XX W 103RD ST	0.6	<0.3	<0.3	<0.3	
10/26/2016	70XX S PERRY AVE	3.9	5.7	5.0	2.4	2.5
4/11/2017	71XX S HONORE ST <b>SITE 1</b>	2.2	4.6	6.5	1.0	
9/8/2017	71XX S HONORE ST <b>SITE 1</b>	2.1	5.4	3.5	1.9	
4/11/2017	71XX S HONORE ST <b>SITE 2</b>	0.9	0.9	1.0	0.5	
9/8/2017	71XX S HONORE ST <b>SITE 2</b>	9.8	1.5	5.9	1.3	1.2
4/11/2017	71XX S HONORE ST <b>SITE 3</b>	1.0	1.2	0.7	0.5	
9/8/2017	71XX S HONORE ST <b>SITE 3</b>	1.4	1.4	2.2	1.5	
5/31/2017	71XX S ROCKWELL ST	2.7	3.1	3.0	2.4	
12/21/2016	72XX N CLAREMONT AVE	2.5	6.8	8.1	1.8	
9/15/2016	72XX N CLAREMONT AVE	2.6	5.3	5.5	3.7	
9/14/2017	72XX S CRANDON AVE	<0.3	0.3	0.4	<0.3	
10/12/2017	72XX S CRANDON AVE	<0.3	1.0	0.4	<0.3	
10/31/2017	72XX S ROCKWELL ST <b>SITE 1</b>	1.7	2.7	2.8	1.4	1.4
5/31/2017	72XX S ROCKWELL ST <b>SITE 1</b>	1.4	2.9	3.4	1.4	
2/6/2018	72XX S ROCKWELL ST <b>SITE 2</b>	1.4	1.6	1.0	0.6	0.6
1/22/2018	72XX S ROCKWELL ST <b>SITE 2</b>	1.6	1.3	1.3	0.7	
10/17/2017	72XX W FITCH AVE	6.2	5.8	12	6.5	
11/7/2017	72XX W FITCH AVE	4.5	5.6	9.4	7.5	5.2
4/11/2017	73XX S HONORE ST	3.1	4.5	4.0	1.3	1.3
9/8/2017	73XX S HONORE ST	4.2	4.2	4.2	3.1	
1/19/2018	73XX S PAXTON AVE	1.9	1.7	2.0	0.8	
2/7/2018	73XX S ROCKWELL ST <b>SITE 1</b>	3.5	3.0	3.3	1.4	
1/12/2018	73XX S ROCKWELL ST <b>SITE 1</b>	3.2	2.8	3.9	1.8	
5/31/2017	73XX S ROCKWELL ST <b>SITE 1</b>	2.9	2.3	2.9	2.1	
12/5/2017	73XX S ROCKWELL ST <b>SITE 1</b>	4.5	5.0	5.4	2.1	
10/31/2017	73XX S ROCKWELL ST <b>SITE 1</b>	3.1	2.7	4.1	3.0	
10/31/2017	73XX S ROCKWELL ST <b>SITE 2</b>	6.2	3.4	3.3	1.9	
6/1/2017	73XX S ROCKWELL ST <b>SITE 2</b>	7.2	5.8	6.0	2.8	
2/14/2017	74XX S CALUMET AVE	3.2	2.8	2.1	0.5	0.4
1/17/2017	74XX S CALUMET AVE	3.6	3.5	4.0	0.6	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
1/19/2018	77XX S DAMEN AVE	2.3	0.4	0.4	<0.3	
2/28/2018	77XX S DAMEN AVE	1.6	0.6	0.5	<0.3	
12/12/2017	77XX S WABASH AVE	3.1	6.5	7.0	2.1	
12/21/2017	77XX S WABASH AVE	3.6	7.4	8.7	2.3	
2/21/2018	77XX W TALCOTT AVE	3.3	3.8	12	1.0	
1/18/2018	77XX W TALCOTT AVE	4.0	4.5	11	1.2	1.2
9/28/2017	78XX S MERRILL AVE	3.0	5.4	7.5	3.4	3.4
2/7/2018	78XX S PAULINA ST	1.6	3.6	3.5	5.1	
1/22/2018	78XX S PAULINA ST	1.9	3.4	3.7	6.9	
12/16/2016	80XX S AVALON AVE	2.9	2.0	2.0	1.0	
2/21/2017	80XX S AVALON AVE	3.2	2.4	2.2	1.0	
3/21/2017	80XX S AVALON AVE	2.7	2.1	2.1	1.1	
1/31/2017	80XX S AVALON AVE	3.6	4.0	4.0	1.1	
4/18/2017	80XX S AVALON AVE	2.7	2.7	2.4	1.2	
5/16/2017	80XX S AVALON AVE	3.6	5.3	4.3	2.1	
8/24/2016	80XX S AVALON AVE	4.0	3.8	3.7	2.4	
12/21/2017	80XX S WABASH AVE	1.4	0.7	1.4	0.4	
12/15/2016	81XX S AVALON AVE	0.7	1.1	1.0	0.4	
8/25/2016	81XX S AVALON AVE	1.1	1.4	1.3	1.1	
2/2/2017	81XX S CHAMPLAIN AVE	7.4	7.1	8.0	2.9	
2/23/2017	81XX S CHAMPLAIN AVE	10	4.9	7.6	3.9	
1/30/2018	81XX S EUCLID AVE	0.7	0.4	0.4	0.4	
2/14/2018	81XX S KILDARE AVE	2.4	3.6	3.7	0.6	
1/17/2018	81XX S WHIPPLE ST	3.5	2.5	1.6	1.0	
2/6/2018	81XX S WHIPPLE ST	2.8	2.5	4.8	1.8	
8/25/2016	82XX S AVALON AVE <b>SITE 1</b>	2.1	1.0	0.7	0.7	
12/15/2016	82XX S AVALON AVE <b>SITE 1</b>	1.2	1.3	0.8	0.7	
12/15/2016	82XX S AVALON AVE <b>SITE 2</b>	1.9	3.2	3.4	1.0	
8/24/2016	82XX S AVALON AVE <b>SITE 2</b>	1.4	7.3	5.0	1.2	
2/21/2017	82XX S AVALON AVE <b>SITE 3</b>	5.9	8.9	5.4	1.3	
1/31/2017	82XX S AVALON AVE <b>SITE 3</b>	4.9	8.3	7.4	1.3	
12/16/2016	82XX S AVALON AVE <b>SITE 3</b>	6.0	7.7	6.2	1.4	
3/21/2017	82XX S AVALON AVE <b>SITE 3</b>	4.8	11	10	1.4	
4/18/2017	82XX S AVALON AVE <b>SITE 3</b>	5.1	7.1	5.9	1.5	
5/16/2017	82XX S AVALON AVE <b>SITE 3</b>	7.9	11	10	2.3	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
8/25/2016	82XX S AVALON AVE <b>SITE 3</b>	7.1	14	13	3.4		
4/4/2017	82XX S KINGSTON AVE	9.5	3.6	3.8	2.3		
4/18/2017	82XX S KINGSTON AVE	7.5	7.5	28	3.0	2.8	
8/1/2017	82XX S KINGSTON AVE	See Follow-Up Sequential Sampling Table for Results					
5/5/2017	82XX S KINGSTON AVE	See Follow-Up Sequential Sampling Table for Results					
2/8/2018	82XX S TRIPP AVE	2.1	1.0	1.4	0.6		
1/12/2018	82XX S TRIPP AVE	2.6	2.7	3.3	0.9		
10/10/2017	83XX S HOYNE AVE	2.2	2.0	2.1	1.0		
10/24/2017	83XX S HOYNE AVE	7.6	2.7	2.4	1.2		
1/19/2018	84XX S KARLOV AVE	1.5	1.2	1.0	0.6		
1/16/2018	85XX S MARSHFIELD AVE	1.1	1.2	0.7	0.3		
1/25/2018	85XX S MARSHFIELD AVE	1.8	1.7	1.8	2.0		
1/24/2018	87XX S SANGAMON ST	1.3	2.0	7.8	1.0		
2/23/2018	87XX S SANGAMON ST	1.4	2.3	8.6	1.1		
7/27/2017	89XX S HAMILTON AVE^	4.9	4.0	3.8	18		
9/9/2017	89XX S HAMILTON AVE^	See Follow-Up Sequential Sampling Table for Results					
2/22/2018	8XX N LAVERGNE AVE	0.9	0.8	0.7	0.4		
1/18/2018	8XX N LAVERGNE AVE	0.7	0.8	0.8	0.4		
12/12/2017	8XX N LAVERGNE AVE	0.7	0.7	0.9	0.5		
11/30/2017	8XX N LAVERGNE AVE	0.7	0.6	0.6	0.6		
11/3/2017	8XX N LAVERGNE AVE	0.9	1.0	0.8	0.7		
9/29/2017	8XX N LAVERGNE AVE	1.4	1.1	1.2	1.3		
5/3/2017	8XX N LAVERGNE AVE	<0.3	<0.3	<0.3	<0.3		
7/27/2017	90XX S HAMILTON AVE <b>SITE 1</b>	2.6	3.9	4.5	2.0		
7/27/2017	90XX S HAMILTON AVE <b>SITE 2</b>	3.7	5.1	4.8	3.5		
10/5/2017	91XX S DREXEL AVE	2.0	8.6	7.6	2.2		
7/27/2017	91XX S HAMILTON AVE	3.4	4.2	3.0	2.0		
1/17/2018	91XX S HOYNE AVE	4.2	3.1	7.4	2.1		
2/23/2018	91XX S HOYNE AVE	4.8	3.0	4.0	2.3		
1/16/2018	92XX S CREGIER AVE	1.2	0.7	0.5	0.5		
2/21/2018	92XX S SANGAMON ST	2.6	0.3	0.4	0.3		
1/19/2018	94XX 12 S PLEASANT AVE	2.0	1.1	0.8	<0.3		
2/21/2018	94XX 12 S PLEASANT AVE	1.0	1.0	0.9	<0.3	<0.3	
2/5/2018	95XX S INDIANA AVE	5.5	5.7	8.4	0.9		
12/22/2017	95XX S INDIANA AVE	5.2	5.5	8.8	1.1		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
1/19/2018	95XX S SEELEY AVE	1.7	2.2	2.2	1.0	
2/27/2018	95XX S SEELEY AVE	1.6	3.6	3.4	1.0	1.0
11/8/2017	96XX S CHARLES ST	1.5	2.5	2.5	1.3	
2/6/2018	96XX S GREEN ST	1.2	1.1	1.2	0.8	
2/13/2018	97XX S CLAREMONT AVE	1.9	2.5	3.0	1.5	
2/13/2018	99XX S WINCHESTER AVE	5.7	7.6	6.0	2.1	
1/23/2018	99XX S WINCHESTER AVE	3.6	6.4	6.9	2.2	
4/24/2017	9XX N LAVERGNE AVE <b>SITE 1</b>	4.3	2.3	2.0	1.3	
9/28/2017	9XX N LAVERGNE AVE <b>SITE 1</b>	3.8	3.3	3.5	2.0	
5/1/2017	9XX N LAVERGNE AVE <b>SITE 2</b>	2.3	1.9	2.8	1.8	
9/29/2017	9XX N LAVERGNE AVE <b>SITE 2</b>	4.1	2.8	6.8	3.6	
4/25/2017	XX E 37TH PL	4.1	5.8	3.5	0.8	
1/29/2018	XX W 83RD ST	2.5	5.2	12	1.9	

\* Water pressure low, could not collect sample

\*\* Samples did not meet study specifications

^ Unable to obtain full sample set

The results listed on this page are from residential homes in Chicago that have volunteered to have their water tested for lead as part of a research study. The data that is shown below is quality controlled. The study is ongoing, and the results below are a small portion of the large sample population necessary for statistical evaluation. The data below will be further reviewed prior to inclusion in statistical evaluation. The results are anonymized to the block level, so the complete address of each home is not posted. In cases where a sample tests over 15 parts per billion (the action limit set by the EPA), the Department of Water Management will contact the homeowner to discuss the results and schedule a time to resample the water and inspect the home's plumbing and electrical wiring to better evaluate possible causes. All results are shown in PPB (Parts per Billion). In cases where multiple homes on the same block have results, the location is further amended as "Site 1", "Site 2", etc.

Follow-Up Sequential Sampling		Sequential Draws										Timed Draws				
Date Sampled	Address	1st Draw	2nd Draw	3rd Draw	4th Draw	5th Draw	6th Draw	7th Draw	8th Draw	9th Draw	10th Draw	3 Minute	5 Minute	7 Minute	10 Minute	15 Minute
10/8/2016	103XX S RACINE AVE	2.19	2.26	4.07	3.71	9.38	15.40	11.50	10.50	11.20	10.20	8.35	4.36			
9/6/2017	107XX S AVENUE N	57.10	28.70	25.10	22.10	20.20	18.90	16.80	17.60	15.40	14.10	5.32	4.28			
11/7/2017	126XX S YALE AVE SITE 2	9.04	10.40	13.10	13.30	13.50	14.20	14.90	16.20	17.40	16.30	13.20	6.39			
11/11/2017	14XX N OAKLEY BLVD	8.99	5.63	6.87	23.90	18.10	12.10	17.30	11.00	8.41	6.96	6.39	5.23			
11/17/2017	16XX N NORMANDY AVE	7.68	7.90	16.10	19.90	19.30	20.80	63.10	26.00	26.20	27.40	21.00	8.70			
10/31/2017	18XX W 34TH ST SITE 5	15.00	16.60	18.10	16.90	15.90	15.10	14.90	15.00	*	*	12.50	6.08			
9/26/2017	18XX W 34TH ST SITE 6	6.20	6.12	8.32	8.37	10.40	12.20	14.70	6.47	3.32	2.84	3.00	2.26			
1/5/2018	20XX W CHASE AVE	4.46	2.99	3.48	5.18	4.56	4.52	5.94	6.80	6.71	6.69	2.65	1.74			
4/4/2017	24XX N HAMLIN AVE**	23.00	5.23	4.29	4.56	4.53	3.48	9.66	8.68	8.57	6.81	3.92	3.32			
11/2/2016	25XX N KEELER AVE	5.07	5.72	3.06	2.65	6.30	11.90	25.00	24.00	12.40	5.70	4.22	3.15			
8/4/2017	26XX N DRAKE AVE SITE 2^	1.61	2.10	1.65	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
4/7/2017	28XX N CHRISTIANA AVE SITE 3	10.40	15.60	14.20	11.90	11.10	10.20	9.54	8.50	8.41	6.53	5.33	4.94	4.60	4.49	4.32
3/3/2017	28XX W 40TH ST**	4.07	3.18	3.16	2.40	3.44	3.92	2.60	4.04	2.73	5.05	3.05	1.36			
9/19/2017	32XX N NAGLE AVE SITE 3	6.31	8.05	7.46	8.40	11.20	14.10	15.70	15.60	*	*	15.20	27.00	4.99	4.15	4.01
8/2/2017	32XX W THOMAS ST	9.55	9.54	9.15	9.45	19.10	43.90	35.30	24.90	23.10	22.40	23.20	8.76	8.37	7.10	6.86
7/10/2017	34XX S MARSHFIELD AVE SITE 2	24.00	28.80	58.20	29.00	21.70	20.30	20.10	13.10	10.50	9.82	9.51	8.93	8.77	8.33	7.95
6/7/2017	36XX S PAULINA ST SITE 3	6.19	2.55	4.78	2.27	2.30	2.58	4.33	2.22	2.13	2.13	1.96	1.91			
5/27/2017	37XX N WHIPPLE ST SITE 6	5.20	6.06	5.11	7.11	6.05	4.51	4.96	3.55	3.49	2.22	2.00	1.57			
5/27/2017	38XX N WHIPPLE ST SITE 2	13.90	23.10	39.80	26.70	27.00	25.30	24.90	24.70	33.10	17.40	6.18	5.30			
8/10/2017	38XX N WHIPPLE ST SITE 2	14.30	21.70	28.20	29.60	30.50	30.00	33.60	38.60	34.80	32.10	10.40	8.32	8.04	7.87	7.61
6/7/2017	39XX N WHIPPLE ST SITE 2	177.00	93.40	123.00	110.00	84.10	70.90	41.50	22.70	42.50	52.90	9.93	7.82			
10/18/2017	39XX N WHIPPLE ST SITE 3	4.87	10.00	10.80	12.30	12.80	16.10	15.10	12.90	10.60	6.20	2.46	2.12	2.11	1.93	1.76
11/22/2017	41XX S MICHIGAN AVE	12.70	12.50	11.60	11.50	16.90	23.10	24.60	23.70	24.20	23.60	19.20	6.18			
11/8/2017	42XX N HAMLIN AVE SITE 4	4.45	7.35	12.30	17.10	15.00	13.30	12.50	11.30	8.25	4.18	3.49	3.37			
1/6/2018	43XX W SCHOOL ST	9.92	11.70	9.59	14.70	16.60	14.70	16.20	16.40	15.80	14.10	10.40	3.33			
10/29/2016	45XX N ALBANY AVE SITE 3	16.30	24.30	34.70	30.50	29.90	26.00	21.60	23.90	24.50	21.40	4.78	4.35			
9/16/2017	45XX N WHIPPLE ST SITE 4	6.66	15.70	31.00	28.20	24.30	21.20	18.80	17.10	14.90	13.10	12.60	6.06	5.59	5.59	4.76
10/26/2017	50XX N WINCHESTER AVE	8.87	9.58	9.48	7.73	8.14	9.04	8.23	7.32	6.80	7.78	6.42	6.83	6.38	5.53	5.40
4/29/2017	53XX N BERNARD ST**	3.95	10.70	17.70	15.50	14.40	13.80	12.60	9.49	5.98	3.22	3.06	1.99			
7/15/2017	53XX N BERNARD ST**	7.58	8.37	8.27	8.40	8.47	8.52	8.14	7.40	7.04	6.81	6.77	5.31			
5/17/2017	57XX W RACE AVE	6.08	7.74	11.70	10.10	9.96	10.70	11.00	9.67	12.30	6.02	5.18	4.78			
12/9/2017	65XX S KILPATRICK AVE SITE 4	<1	<1	<1	<1	1.26	1.51	1.60	2.04	2.11	1.76	*	<1	<1	<1	<1
9/29/2017	66XX S KILPATRICK AVE SITE 5	1.73	23.10	4.67	4.19	4.88	3.79	2.18	2.12	1.73	1.90	2.33	1.36			
6/9/2017	67XX N JEAN AVE	2.56	3.31	4.24	10.50	13.90	14.90	17.60	12.70	19.90	21.60	4.21	2.03			
5/5/2017	82XX S KINGSTON AVE	5.54	3.96	3.06	12.50	26.90	14.20	13.20	30.90	20.60	5.13	9.49	2.79			
8/1/2017	82XX S KINGSTON AVE	13.10	3.00	3.05	3.84	6.53	8.34	11.60	9.71	9.46	14.40	8.20	3.10	3.16	2.92	2.65
9/9/2017	89XX S HAMILTON AVE^	5.12	6.39	6.69	7.95	7.27	6.66	6.45	6.60	6.48	6.17	5.51	5.00			

\* Water pressure low, could not collect sample

\*\* Samples did not meet study specifications

^ Unable to obtain full sample set